






Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME AMERICAS BEST VALUE INN & SUITES		DATE 6/11/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 7/31/2015
LOCATION 2425 S ARCHIBALD AV, ONTARIO, CA 91761			INSPECTOR Veronica Martinez	
MAILING ADDRESS 2425 S ARCHIBALD AV, ONTARIO, CA 91761			IDENTIFIER: Pool	
TIME IN 1:50 PM	TIME OUT 2:13 PM	FACILITY ID FA0004833	RELATED ID PR0013537	PE 3620
			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE ACTION: 01 - NO FURTHER ACTION REQUIRED	

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K992 Permit Reinstatement

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Critical violation cited during last routine inspection observed in compliance; free chlorine residual measured at 0.06 ppm.
	Not In Compliance Violation Reference - HSC	
Pool permit has been re-instated and pool is authorized to open by Division of Environmental Health Services (DEHS).		

Description: The health permit to operate is hereby reinstated and facility may open.

36K994 Reinspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: A reinspection was conducted today in regard to high free chlorine residual observed during the last routine inspection.
	Not In Compliance Violation Reference - HSC	
Upon inspection, observed free chlorine residual measuring 0.06 ppm. Maintain free chlorine residual between 2.0 ppm and 10.0 ppm in the presence of cyanuric acid.		
Observed welding technician actively repairing/securing vertical member of fencing observed unfastened at bottom joint during the last routine inspection.		
Observed pH measuring 7.2, cyanuric acid measuring 69.3 ppm, and directional symbols provided.		
Facility may reopen.		

Description: Reinspection conducted at this time to determine compliance from prior inspection.

36K504 Water Quality – Non-Critical – Disinfectant level low

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed free chlorine residual measuring 0.06 ppm. Maintain free chlorine residual between 2.0 ppm and 10.0 ppm in the presence of cyanuric acid.
	Not In Compliance Violation Reference - HSC - 65529	

Violation Description: The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

Overall Inspection Comments

No summary comments have been made for this inspection.



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME AMERICAS BEST VALUE INN & SUITES	DATE 6/11/2015
LOCATION 2425 S ARCHIBALD AV, ONTARIO, CA 91761	INSPECTOR Veronica Martinez

Signature(s) of Acknowledgement

NAME: P.C. Shaw
TITLE: Manager

Total # of Images: 0