






Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME LAS CASITAS		DATE 8/17/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 10/31/2015
LOCATION 1002 NOCTA A, ONTARIO, CA 91764			INSPECTOR John Ramos	
MAILING ADDRESS 2005 HOLLY AV, ARCADIA CA 91007			IDENTIFIER: Pool	
TIME IN 1:52 PM			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
TIME OUT 2:20 PM			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU	
FACILITY ID FA0008425			ACTION: 13 - PERMIT SUSPENDE / FACILITY CLOSED	
RELATED ID PR0015731			PE 3620	

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	80
volume (gal)	29,920
area (sq ft)	800
occupancy	40

IMPORTANT: Replacement of Suction Outlet Covers
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K995 Permit - Suspension **⚠ CRITICAL ⚠**

POINTS
NA

Comply by: 8/19/2015
 Not In Compliance
 Violation Reference - HSC

Inspector Comments: Health permit continues to be suspended. Notice of Closure re-posted. Do not remove sign or reopen pool without authorization from Environmental Health.

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K514 Water Quality – Critical – Water clarity **⚠ CRITICAL ⚠**

POINTS
5

Comply by: 8/19/2015
 Not In Compliance
 Violation Reference - HSC - 65527

Inspector Comments: Observed green swimming pool, main drain is not visible. Provide clear pool water.

Violation Description: The pool operator shall maintain clear pool water while the public pool is in use. The pool operator shall close the public pool if the bottom of the pool at the maximum depth is not clearly visible from the deck. The pool operator shall not reopen the public pool for use until the pool water is clean and clear, and the bottom of the pool at the maximum depth is clearly visible from the deck. If the bottom of the pool is not visible 48 hours following inspection and closure by the enforcing agent, the enforcing agent may order the pool drained.



Public Health

Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME LAS CASITAS	DATE 8/17/2015
LOCATION 1002 NOCTA A, ONTARIO, CA 91764	INSPECTOR John Ramos

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K527 Safety – Safety signs

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed the local emergency phone number and facility address have not been provided on any sign. Provide signs with this information.
	Not In Compliance	
	Violation Reference - CCR - 3120B	
	Observed no "Keep Closed" sign on the gate. Provide sign.	
	Observed no diarrhea warning sign posted. Provide sign.	
	Observed pool / spa capacity not listed on the safety signs. Provide capacity.	
	Observed no CPR instructions on any safety signs. Provide signs with CPR instructions.	

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- Maximum number of pool users permitted for each pool.
- "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- A warning sign for spa pools with "CAUTION" language.
- Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

36K528 Safety – Safety equipment

POINTS 1	Comply by: 8/19/2015	Inspector Comments: Observed no life ring present in pool area. Provide a life ring in pool area.
	Not In Compliance	
	Violation Reference - HSC - 65540	
	Observed no rescue pole present in pool area. Ensure to provide a rescue pole in pool area.	

Violation Description: Except for spray grounds without standing water, the pool operator shall ensure that the following safety and first aid equipment is provided and maintained readily visible and available for use at the public pool at all times:

- (1) A 17-inch-minimum (exterior diameter) life ring with an attached throw rope with a minimum 3/16-inch diameter. The throw rope shall be of sufficient length to span the maximum width of the public pool and shall be stored in such a way as to prevent kinking or fouling.
- (2) A 12-foot-minimum fixed-length rescue pole with a permanently attached body hook. For spas, the length of the rescue pole shall be of sufficient length to effectuate rescue.

For public pools that exceed 75 feet in length or 50 feet in width, the pool operator shall provide a rescue pole and a life ring on at least two opposing sides of the public pool at centralized locations.

For public pools with lifeguard personnel on duty, the pool operator of each public pool area shall have the following additional safety equipment:

- (1) A Red Cross 10-Person Industrial First Aid Kit or the equivalent.
- (2) An operating telephone.
- (3) A backboard and head immobilizer.



Public Health

Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME LAS CASITAS	DATE 8/17/2015
LOCATION 1002 NOCTA A, ONTARIO, CA 91764	INSPECTOR John Ramos

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K572 Maintenance – Pool shell cleanliness; slime and algae

POINTS 1	Comply by: 8/19/2015
	Not In Compliance
	Violation Reference - HSC - 65533

Inspector Comments: Observed heavy algae growth on pool shell surfaces.
Clean and remove algae.

Violation Description: (a) The pool operator shall maintain clean pool water while the public pool is in use. The pool operator shall not allow debris, including, but not limited to, floating scum, sputum, trash, or leaves, to accumulate in the public pool. The pool operator shall ensure that water levels are maintained and operated to remove such material continuously through the pool skimming system in accordance with section 3136B, Title 24, California Code of Regulations.

(b) The pool operator shall clean the bottom, sides, and other surfaces of the public pool as often as necessary to keep the bottom, sides, and public pool surfaces clean and free of slime and algae.

36K596 Permit - Public Pool Closure

POINTS NA	Comply by: 8/19/2015
	Not In Compliance
	Violation Reference - HSC - 65545

Inspector Comments: Pool/spa closed. Notice of Closure posted. Do not remove sign or reopen pool without authorization from Environmental Health.

Description: A public pool that is maintained or operated in a manner that creates an unhealthful, unsafe, or unsanitary condition may be closed by the enforcing agent. Unhealthful, unsafe, or unsanitary conditions include, but are not limited to, failure to maintain clean pool water and clear pool water requirements; inadequate disinfection; improper pH; the presence of inhalation hazards; failure to meet microbiological or chemical water-quality standards; missing or broken suction outlet covers; missing or broken pool enclosures, including fencing and gates; hazards to pool users; and any other violation of these regulations identified by the enforcing agent. A public pool shall not be reopened until the unhealthful, unsafe, or unsanitary condition has been rectified and upon specific written approval from the enforcing agent.

Overall Inspection Comments

Health permit continues to be suspended. Notice of Closure re-posted. Do not remove sign or reopen pool without authorization from Environmental Health.

Correct the above noted violations.

If you have any questions contact John Ramos at (800) 442-2283 or at John.Ramos@dph.sbcounty.gov

Signature(s) of Acknowledgement

NAME:
TITLE:

Total # of Images: 0