



**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

|  |                            |   |                                |                                       |   |
|--|----------------------------|---|--------------------------------|---------------------------------------|---|
| FACILITY NAME<br><b>CALIFORNIA INN</b>               |                            | REINSPECTION DATE<br><b>Not Specified</b> |                                | INSPECTOR<br><b>Ahn Tran</b>          | DATE<br><b>8/11/2016</b>                        |
| LOCATION<br><b>1431 E MAIN ST, BARSTOW, CA 92311</b> |                            |   |                                | PERMIT EXPIRATION<br><b>5/31/2017</b> | IDENTIFIER: Pool                                |
| TIME IN<br><b>1:10 PM</b>                            | TIME OUT<br><b>1:45 PM</b> | FACILITY ID<br><b>FA0008643</b>           | RELATED ID<br><b>PR0015697</b> | PE<br><b>3620</b>                     | SERVICE: 001 - INSPECTION - ROUTINE             |
|  |                            |   |                                |                                       | RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU |
|  |                            |   |                                |                                       | ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED |

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

**95**  
SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

|                   |
|-------------------|
| Ideal             |
| In Compliance     |
| Not in Compliance |



|                     |         |
|---------------------|---------|
| temperature (°F)    | No Data |
| observed flow (gpm) | No Data |
| required flow (gpm) | 95      |
| volume (gal)        | 30,000  |
| area (sq ft)        | 800     |
| occupancy           | 40      |

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K995 Permit - Suspension** **⚠ CRITICAL ⚠**

|                            |                                |                            |
|----------------------------|--------------------------------|----------------------------|
| <b>POINTS</b><br><b>NA</b> | Compliance Date: Not Specified | <b>Inspector Comments:</b> |
|                            | Not In Compliance              |                            |
|                            | Violation Reference - HSC      |                            |

**Violation Description:** Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

**36K506 Water Quality - Critical – Water pH 7.2 to 7.8** **⚠ CRITICAL ⚠**

|                           |                                   |  |
|---------------------------|-----------------------------------|--|
| <b>POINTS</b><br><b>5</b> | Compliance Date: Not Specified    | <b>Inspector Comments:</b> Observed the pH at 6.61 at this time. |
|                           | Not In Compliance                 |  |
|                           | Violation Reference - HSC - 65530 |  |

**Violation Description:** The pool operator shall maintain public pool water at pH 7.2 to 7.8.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Signature(s) of Acknowledgement**

NAME:  
TITLE:



**Public Health**  
Environmental Health Services

[www.SBCounty.gov](http://www.SBCounty.gov)  
[www.SBCounty.gov/dph/dehs](http://www.SBCounty.gov/dph/dehs)

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

|   |                       |
|---|-----------------------|
| FACILITY NAME<br>CALIFORNIA INN               | DATE<br>8/11/2016     |
| LOCATION<br>1431 E MAIN ST, BARSTOW, CA 92311 | INSPECTOR<br>Ahn Tran |

Total # of Images: 0