



Public Health
Environmental Health Services

RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT

FACILITY NAME ROUND TABLE PIZZA			REINSPECTION DATE Not Specified	INSPECTOR Zaynab Darwiche	DATE 3/21/2022
LOCATION 14898 DALE EVANS PKWY 200, APPLE VALLEY, CA 92307			PERMIT EXPIRATION	IDENTIFIER: None	
TIME IN 11:00 AM	TIME OUT 11:35 AM	FACILITY ID FA0016195	RELATED ID CO0082544	PE 1622	SERVICE: 004 - COMPLAINT - INITIAL RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED

RETAIL FOOD PROTECTION - Public Eating PI (100-Up Seats)

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

16K999 Complaint Inspection

Compliance Date: Not Specified

Inspector Comments: Environmental Health received a complaint on 3/21/2022 stating there is a sewage overflow in the parking lot.

Reference - HSC

Discussed nature of complaint with owner is aware of overflow.

Upon arrival to facility, code enforcement officer arrived for the same complaint against Round Table Pizza.

Code enforcement stated that public works came out the night before due to a strong sewage odor coming from Round Table Pizza's grease interceptors located in parking lot.

After draining three compartment and prep sinks into floor sinks, active sewage overflow was observed from the Round Table grease interceptor in the parking lot from two interceptor man hole covers.

Owner stated overflow began Thursday, 3/17/2022, however grease interceptors have not been serviced. Per owner, grease interceptors are serviced quarterly with the last service conducted 01/2022.

Permit suspended and facility closed due to active sewage overflow. Permit shall remain suspended and facility will remain closed until reinspected by EHS once sewage overflow is eliminated.

During complaint investigation, plumber arrived and stated that the grease interceptors will be jetted however they will not be cleaned. According to Apple Valley code enforcement, the interceptors are required to be cleaned prior to reopening for operation.

Contact EHS for reinspection.

Description: A complaint report has been received by Environmental Health.

16K054 Permit Suspension



Compliance Date: Not Specified

Inspector Comments: Permit suspended and facility closed due to active sewage overflow. Permit shall remain suspended and facility will remain closed until sewage overflow is eliminated.

Not In Compliance

Violation Reference - HSC - 114409, 114405

Contact Environmental Health Services for reinspection.

Violation Description: If an imminent health hazard is found, an enforcement officer may temporarily suspend the permit and order the food facility immediately closed. (114409, 114405)

Overall Inspection Comments

Complaint investigation conducted on this day.

FREE Classes to L.E.A.R.N!

Liaison Education And Risk Network (L.E.A.R.N.) is a FREE class based on the fundamentals of Active Managerial Control and the Centers for Disease Control and Prevention's five risk factors that lead to foodborne illnesses. Find out when the next L.E.A.R.N. class is by checking our [calendar](#).

Signature(s) of Acknowledgement

No Sig

NAME: Sam Sandhu
TITLE: Owner



Public Health
Environmental Health Services

RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT

<small>FACILITY NAME</small> ROUND TABLE PIZZA	<small>DATE</small> 3/21/2022
<small>LOCATION</small> 14898 DALE EVANS PKWY 200, APPLE VALLEY, CA 92307	<small>INSPECTOR</small> Zaynab Darwiche

Total # of Images: 0