



**Public Health**  
**Environmental Health Services**

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME MECCA TRAILER PARK		DATE 7/24/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2014
LOCATION 108 CAL AV, BARSTOW, CA 92311			INSPECTOR Michelle Saltis	
MAILING ADDRESS 198 N ARROWHEAD AV, SAN BERNARDINO CA 92408			IDENTIFIER: Pool	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN 2:03 PM	TIME OUT 2:44 PM	FACILITY ID FA0008639	RELATED ID PR0014374	PE 3620
			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
			ACTION: 01 - NO FURTHER ACTION REQUIRED	

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.




**95**

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	70
required flow (gpm)	75
volume (gal)	27,000
area (sq ft)	600
occupancy	30

**IMPORTANT: Replacement of Suction Outlet Covers**  
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K508 Water Quality – Non-Critical – Water pH 7.2 to 7.8**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	Inspector Comments: Maintain pH between 7.2-7.8 in pool water.
	Not In Compliance	Observed pH in pool water measuring at 6.9.
	Violation Reference - HSC - 65530	

Violation Description: The pool operator shall maintain public pool water at pH 7.2 to 7.8.

**36K518 Water Quality – Cyanuric acid concentration**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	Inspector Comments: Maintain cyanuric acid below 100ppm.
	Not In Compliance	Observed cyanuric acid in pool water measuring at or above 111ppm.
	Violation Reference - HSC - 65530	

Violation Description: The maximum concentration of cyanuric acid in public pool water shall not exceed 100.0 ppm.



## Public Health Environmental Health Services

[www.SBCounty.gov](http://www.SBCounty.gov)

### RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME <b>MECCA TRAILER PARK</b>	DATE <b>7/24/2015</b>
LOCATION <b>108 CAL AV, BARSTOW, CA 92311</b>	INSPECTOR <b>Michelle Saltis</b>

#### IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

#### 36K527 Safety – Safety signs

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR - 3120B	<b>Inspector Comments:</b> Immediately provide the nearest emergency contact phone number and site location address on safety sign. Did not observe the nearest emergency contact phone number and site location address posted on safety sign.  Provide "keep gate closed" sign on gate. Did not observe "keep gate closed" sign posted on gate.  Provide the maximum capacity on safety sign not to exceed 30. Did not observe maximum capacity posted.

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

#### 36K556 Equipment – Plumbing labeled

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR 24 - 3120B	<b>Inspector Comments:</b> Provide directional symbols on pool piping in pump area.  Did not observe directional arrows indicating the flow of the pool water recirculation.

**Violation Description:** The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area. Where the recirculation equipment for more than one pool is located on site, the equipment shall be marked as to which pool the system serves. Valves and plumbing lines shall be labeled clearly with the source or destination descriptions.

#### 36K582 Maintenance - Public pool site maintenance

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified Not In Compliance Violation Reference - HSC - 65535	<b>Inspector Comments:</b> Tighten the hand rails on the North East side of the pool.  Observed handrails on the North East side of the pool loose.

**Violation Description:** The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

#### Overall Inspection Comments

No summary comments have been made for this inspection.

#### Signature(s) of Acknowledgement



**Public Health**  
**Environmental Health Services**

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>MECCA TRAILER PARK</b>	DATE <b>7/24/2015</b>
LOCATION <b>108 CAL AV, BARSTOW, CA 92311</b>	INSPECTOR <b>Michelle Saltis</b>

A handwritten signature in blue ink, appearing to read "Matthew Chavez".

NAME: Matthew Chavez  
TITLE: Mgr

Total # of Images: 0