



Public Health
Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME ORCHARD LANE CONDO		DATE 6/17/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2015
LOCATION 1380 MAXWELL , UPLAND, CA 91786			INSPECTOR Nicole Walker	
MAILING ADDRESS 1693 W 9TH ST, UPLAND CA 91786			IDENTIFIER: North Pool	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN 2:12 PM	TIME OUT 2:42 PM	FACILITY ID FA0008542	RELATED ID PR0015374	PE 3620
RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE				
ACTION: 01 - NO FURTHER ACTION REQUIRED				




RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

99
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$ 4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K588 Restrooms - Toilet facilities/Showers

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed shower in need of repair.
	Not In Compliance	
	Violation Reference - CCR - 3116B	

Violation Description: Separate toilet facilities shall be provided for each sex. One toilet shall be provided for every 60 women or less and one toilet plus one urinal for every 75 men or less. One lavatory shall be provided for every 80 pool users.

Shower and dressing facilities shall be provided for users of a pool.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME:
TITLE:
Total # of Images: 0