



Public Health
Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME NEWPORT VILLAGE APTS		DATE 5/5/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 7/31/2015
LOCATION 1455 E DATE ST, SAN BERNARDINO, CA 92404			INSPECTOR Anies Kondoker	
MAILING ADDRESS 1455 E DATE ST, SAN BERNARDINO, CA 92404			IDENTIFIER: Pool	
<input checked="" type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT			SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN 11:22 AM	TIME OUT 12:17 PM	FACILITY ID FA0008115	RELATED ID PR0015610	PE 3620
			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQ	
			ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED	

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

100

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K995 Permit - Suspension ⚠ CRITICAL ⚠

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Pool permit is suspended due to non-operational recirculation system at this time.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K544 Equipment – Critical – Water treatment system operation ⚠ CRITICAL ⚠

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Observed pump turned off during inspection. Ensure that pool recirculation system is fully functional during pool open hours.
	Not In Compliance	
	Violation Reference - HSC - 65525	

Violation Description: The pool operator shall operate pumps, filters, disinfectant and chemical feeders, flow indicators, gauges, recirculation systems, disinfection systems, and all parts of the water treatment system whenever the public pool is available for use, and at such additional times and periods as may be necessary to maintain clean pool water, clear pool water, and the disinfection standards required in section 65529 [Health and Safety Code].



Public Health

Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME NEWPORT VILLAGE APTS	DATE 5/5/2015
LOCATION 1455 E DATE ST, SAN BERNARDINO, CA 92404	INSPECTOR Anies Kondoker

36K527 Safety – Safety signs

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Observed faded safety sign on pool rules. Replace.
	Not In Compliance	
	Violation Reference - CCR - 3120B	Observed missing the following safety signs:
		<ul style="list-style-type: none"> - An illustrated diagram with text at least ¼" high of CPR procedures. - The emergency telephone number 911 with number at least 4" high. - Phone number of the nearest emergency services. - Name and address of the pool facility with number and text at least 1" high. - Keep gate closed and diarrhea sign.
		Provide the above signs within 1 month.

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

36K528 Safety – Safety equipment

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Observed missing life ring and rescue pole in the pool enclosure. Provide an approved life ring (with an approved rope attached to it) and a rescue pole that is at least 12 ft long with a body hook attached to it.
	Not In Compliance	
	Violation Reference - HSC - 65540	

Violation Description: Except for spray grounds without standing water, the pool operator shall ensure that the following safety and first aid equipment is provided and maintained readily visible and available for use at the public pool at all times:

- (1) A 17-inch-minimum (exterior diameter) life ring with an attached throw rope with a minimum 3/16-inch diameter. The throw rope shall be of sufficient length to span the maximum width of the public pool and shall be stored in such a way as to prevent kinking or fouling.
- (2) A 12-foot-minimum fixed-length rescue pole with a permanently attached body hook. For spas, the length of the rescue pole shall be of sufficient length to effectuate rescue.

For public pools that exceed 75 feet in length or 50 feet in width, the pool operator shall provide a rescue pole and a life ring on at least two opposing sides of the public pool at centralized locations.

For public pools with lifeguard personnel on duty, the pool operator of each public pool area shall have the following additional safety equipment:

- (1) A Red Cross 10-Person Industrial First Aid Kit or the equivalent.
- (2) An operating telephone.
- (3) A backboard and head immobilizer.

36K548 Equipment - Recirculation system components

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Observed no sight glass in the line between filter and separation tank. Install the sight glass.
	Not In Compliance	
	Violation Reference - CCR - 3123B, 3138B	

Violation Description: Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The system shall consist of pumps, filters, chemical feeders, skimmers or perimeter overflow systems, valves, pipes, connections, fittings and appurtenances.

A spa pool aeration and/or jet system shall be completely separate from the recirculation system and shall not be interconnected with any other pool.



Public Health

Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME NEWPORT VILLAGE APTS	DATE 5/5/2015
LOCATION 1455 E DATE ST, SAN BERNARDINO, CA 92404	INSPECTOR Anies Kondoker

36K556 Equipment – Plumbing labeled

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Observed recirculation equipment not labeled with direction of flow. Ensure to label recirculation equipment with directional symbols such as arrows on all piping.
	Not In Compliance	
	Violation Reference - CCR - 3120B	

Violation Description: The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area. Where the recirculation equipment for more than one pool is located on site, the equipment shall be marked as to which pool the system serves. Valves and plumbing lines shall be labeled clearly with the source or destination descriptions.

36K562 Skimmers – Pool skimming systems

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Observed missing weir gate in both skimmers. Replace.
	Not In Compliance	
	Violation Reference - CCR - 3123B	

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 100 percent of the flow rate. Each surface skimmer shall comply with the requirements in accordance with section 3136B, Title 24, California Code of Regulations.

36K570 Maintenance – Non-Critical – Flow rate/Turnover rate

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Observed non-readable flow meter. Repair/replace. Ensure that recirculation system is able to achieve flow rate within 75% of required flow rate of 34 gpm.
	Not In Compliance	
	Violation Reference - CCR - 3124B, 65525	

Violation Description: The recirculation system shall have the capacity to provide a complete turnover of pool water in:

1. One-half hour or less for a spa pool; and
2. One-half hour or less for a spray ground; and
3. One hour or less for a wading pool; and
4. Two hours or less for a medical pool; and
5. Six hours or less for all other types of public pools.

The variation in flow rate of an operating recirculation system shall be such as not to reduce the flow below 75 percent of the rate required in section 3124B, Title 24, California Code of Regulations.

36K572 Maintenance – Pool shell cleanliness; slime and algae

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Observed chipped pool shell and coping. Repair.
	Not In Compliance	
	Violation Reference - HSC - 65533	

Violation Description: (a) The pool operator shall maintain clean pool water while the public pool is in use. The pool operator shall not allow debris, including, but not limited to, floating scum, sputum, trash, or leaves, to accumulate in the public pool. The pool operator shall ensure that water levels are maintained and operated to remove such material continuously through the pool skimming system in accordance with section 3136B, Title 24, California Code of Regulations.

(b) The pool operator shall clean the bottom, sides, and other surfaces of the public pool as often as necessary to keep the bottom, sides, and public pool surfaces clean and free of slime and algae.

36K582 Maintenance - Public pool site maintenance

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Observed some large rocks and a metal pole on a pool deck. Ensure to maintain pool area clean and free of litter. Observed missing drain cover on pool deck. Replace.
	Not In Compliance	
	Violation Reference - HSC - 65535	

Violation Description: The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

Overall Inspection Comments



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME NEWPORT VILLAGE APTS	DATE 5/5/2015
LOCATION 1455 E DATE ST, SAN BERNARDINO, CA 92404	INSPECTOR Anies Kondoker

According to a manager and a maintenance person, the pool and spa has been closed for more than 17 years. A pool service company comes once a week to treat the water.

Owner of this facility has the following options:

1. If there's water in pool and spa, the pool and spa have to meet all current regulations. Correct all the violations by July 5, 2015.
2. If current regulations can't be met, both pool and spa must be drained or demolished.

Call health dept for more information.

ENSURE TO PROVIDE RECORDS OF EXPIRATION TIME OF MAIN DRAIN AND EQUILIZER LINE COVERS. THE COVERS SHALL BE REPLACED BEFORE THEY ARE EXPIRED.

Provide the records within 1 month.

Signature(s) of Acknowledgement

NAME:
 TITLE:

Total # of Images: 0