



**Public Health**  
**Environmental Health Services**

www.SBCounty.gov

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>RED HILL COUNTRY CLUB</b>				DATE <b>8/13/2015</b>	REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>12/31/2015</b>
LOCATION <b>8358 RED HILL COUNTRY CLUB DR, RANCHO CUCAMONGA, CA 91730</b>					INSPECTOR <b>Dior Porter</b>	
MAILING ADDRESS <b>8358 RED HILL COUNTRY CLUB DR, RANCHO CUCAMONGA, CA 91730</b>					IDENTIFIER: Pool	
<input checked="" type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT					SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN <b>11:02 AM</b>	TIME OUT <b>12:15 PM</b>	FACILITY ID <b>FA0007682</b>	RELATED ID <b>PR0013571</b>	PE <b>3620</b>	RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
					ACTION: 01 - NO FURTHER ACTION REQUIRED	

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.




**99**

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	200
required flow (gpm)	416
volume (gal)	150,000
area (sq ft)	1,875
occupancy	94

**IMPORTANT: Replacement of Suction Outlet Covers**  
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K528 Safety – Safety equipment**

**POINTS**  
**1**

Compliance Date: Not Specified  
 Not In Compliance  
 Violation Reference - HSC - 65540

**Inspector Comments:** Observed missing line to life ring. Attach an approved line to the ring.

**Violation Description:** Except for spray grounds without standing water, the pool operator shall ensure that the following safety and first aid equipment is provided and maintained readily visible and available for use at the public pool at all times:

- (1) A 17-inch-minimum (exterior diameter) life ring with an attached throw rope with a minimum 3/16-inch diameter. The throw rope shall be of sufficient length to span the maximum width of the public pool and shall be stored in such a way as to prevent kinking or fouling.
- (2) A 12-foot-minimum fixed-length rescue pole with a permanently attached body hook. For spas, the length of the rescue pole shall be of sufficient length to effectuate rescue.

For public pools that exceed 75 feet in length or 50 feet in width, the pool operator shall provide a rescue pole and a life ring on at least two opposing sides of the public pool at centralized locations.

For public pools with lifeguard personnel on duty, the pool operator of each public pool area shall have the following additional safety equipment:

- (1) A Red Cross 10-Person Industrial First Aid Kit or the equivalent.
- (2) An operating telephone.
- (3) A backboard and head immobilizer.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Signature(s) of Acknowledgement**



**Public Health**  
**Environmental Health Services**

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>RED HILL COUNTRY CLUB</b>	DATE <b>8/13/2015</b>
LOCATION <b>8358 RED HILL COUNTRY CLUB DR, RANCHO CUCAMONGA, CA 91730</b>	INSPECTOR <b>Dior Porter</b>

NAME:  
TITLE:

**Total # of Images: 0**