



**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>CAMP CEDAR FALLS</b>		REINSPECTION DATE <b>Not Specified</b>		INSPECTOR <b>Michelle Lamont</b>	DATE <b>6/23/2016</b>
LOCATION <b>39850 HWY 38 , ANGELUS OAKS, CA 92305</b>				PERMIT EXPIRATION <b>12/31/2016</b>	IDENTIFIER: Pool
TIME IN <b>11:00 AM</b>	TIME OUT <b>12:00 PM</b>	FACILITY ID <b>FA0007080</b>	RELATED ID <b>PR0004043</b>	PE <b>3620</b>	SERVICE: 001 - INSPECTION - ROUTINE RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE ACTION: 01 - NO FURTHER ACTION REQUIRED

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

**93**  
SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	190
volume (gal)	64,500
area (sq ft)	1,500
occupancy	75

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K527 Safety – Safety signs**

<b>POINTS</b> <b>1</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed improper wording on entrance gate (sign says KEEP CLOSED) and faded facility name/address and number to nearest emergency services.  Sign on entrance gate must state KEEP GATE CLOSED or KEEP DOOR CLOSED in minimum 4 inch lettering. Write in facility name/address and number to nearest emergency services so it is legible in minimum 1 inch lettering.
	<b>Not In Compliance</b>	
	Violation Reference - <b>CCR - 3120B</b>	

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) ""NO DIVING"" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, ""WARNING: NO LIFEGUARD ON DUTY."" The sign also shall state in letters at least 1 inch high, ""Children under the age of 14 shall not use pool without a parent or adult guardian in attendance.""
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with ""CAUTION"" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, ""NO USE OF POOL ALLOWED AFTER DARK.""
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, ""KEEP GATE CLOSED"" or ""KEEP DOOR CLOSED"".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, ""CAUTION: WATER IS RECIRCULATED. DO NOT DRINK.""



## RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME CAMP CEDAR FALLS	DATE 6/23/2016
LOCATION 39850 HWY 38, ANGELUS OAKS, CA 92305	INSPECTOR Michelle Lamont

### 36K528 Safety – Safety equipment

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed no body hook on pole, deteriorating life ring rope and life ring in disrepair.  Provide body hook on minimum 12 foot nonadjustable pole and repair/replace life ring and life ring rope (rope must be long enough to span the maximum width of the pool).
	Not In Compliance Violation Reference - HSC - 65540	

**Violation Description:** Except for spray grounds without standing water, the pool operator shall ensure that the following safety and first aid equipment is provided and maintained readily visible and available for use at the public pool at all times:

- (1) A 17-inch-minimum (exterior diameter) life ring with an attached throw rope with a minimum 3/16-inch diameter. The throw rope shall be of sufficient length to span the maximum width of the public pool and shall be stored in such a way as to prevent kinking or fouling.
- (2) A 12-foot-minimum fixed-length rescue pole with a permanently attached body hook. For spas, the length of the rescue pole shall be of sufficient length to effectuate rescue.

For public pools that exceed 75 feet in length or 50 feet in width, the pool operator shall provide a rescue pole and a life ring on at least two opposing sides of the public pool at centralized locations.

For public pools with lifeguard personnel on duty, the pool operator of each public pool area shall have the following additional safety equipment:

- (1) A Red Cross 10-Person Industrial First Aid Kit or the equivalent.
- (2) An operating telephone.
- (3) A backboard and head immobilizer.

### 36K546 Equipment – Non-Critical - Water treatment system operation

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Recirculation equipment was currently not in operation due to a leak in the backwash piping. Operator was repairing the leak.  Repair leak.
	Not In Compliance Violation Reference - HSC - 65525	

**Violation Description:** The pool operator shall operate pumps, filters, disinfectant and chemical feeders, flow indicators, gauges, recirculation systems, disinfection systems, and all parts of the water treatment system whenever the public pool is available for use, and at such additional times and periods as may be necessary to maintain clean pool water, clear pool water, and the disinfection standards required in section 65529 [Health and Safety Code].

### 36K565 Decking - Requirements

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed uneven and deteriorating decking at the deep end by the entrance.  Repair deteriorating decking so that is it flush with the surrounding decking to prevent any tripping hazards.
	Not In Compliance Violation Reference - CCR 24 - 3114B	

**Violation Description:** A minimum continuous and unobstructed 4-foot wide (1219 mm) slip resistant, cleanable, nonabrasive deck area of concrete or like material shall be provided flush with the top of the pool coping extending completely around the pool, and the deck area shall further extend 4 feet (1219 mm) on both sides and rear of any diving board, fixed disabled access assistance device or slide and their appurtenances. The deck width shall be measured from the poolside edge of the coping lip.

### 36K572 Maintenance – Pool shell cleanliness; slime and algae

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed dirt/leaves on bottom of shell.  Clean and maintain the shell to be free of debris/leaves.
	Not In Compliance Violation Reference - HSC - 65533	

**Violation Description:** (a) The pool operator shall maintain clean pool water while the public pool is in use. The pool operator shall not allow debris, including, but not limited to, floating scum, sputum, trash, or leaves, to accumulate in the public pool. The pool operator shall ensure that water levels are maintained and operated to remove such material continuously through the pool skimming system in accordance with section 3136B, Title 24, California Code of Regulations.

(b) The pool operator shall clean the bottom, sides, and other surfaces of the public pool as often as necessary to keep the bottom, sides, and public pool surfaces clean and free of slime and algae.

### 36K574 Maintenance – Test kit

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed OTO type test kit on deck.  Discontinue using OTO type test kit. Ensure that DPD type chlorine test kit is used so that free chlorine is measured.
	Not In Compliance Violation Reference - HSC - 65529	

**Violation Description:** The pool operator shall maintain a test kit for measuring the disinfectant residual, pH, and, if used, cyanuric acid concentration at the public pool. This test kit shall be available for use by the pool operator and the enforcing agent at all times the public pool is in use. The chlorine or bromine test kit shall be the diethyl-p-phenylenediamine (DPD) type or otherwise be capable of testing free-halogen residual.



**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>CAMP CEDAR FALLS</b>	DATE <b>6/23/2016</b>
LOCATION <b>39850 HWY 38 , ANGELUS OAKS, CA 92305</b>	INSPECTOR <b>Michelle Lamont</b>

**36K582 Maintenance - Public pool site maintenance**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> a) Observed both hand rails loose in the shallow end.  Secure loose hand rails.  b) Observed missing waterline tiles by the skimmer in the shallow end.  Repair/replace missing water line tiles.  c) Observed water in light. GFCI is functional. Operator disconnected breaker to lights. Lights no longer turn on.  Repair light so there is no water inside. Post a sign that states "No swimming after dark" until repair has been completed.
	Not In Compliance Violation Reference - HSC - 65535	

**Violation Description:** The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

**Overall Inspection Comments**

Note: Unable to check flow rate as recirculation equipment was turned off due to fixing a leak. Flow rate should be at 190 GPM. Ensure that flow meter is accurate within 10% of the actual flow.

**Signature(s) of Acknowledgement**

SNA

NAME:  
TITLE:

Total # of Images: 0