



**Public Health**  
Environmental Health Services

www.SBCounty.gov

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME COLTON COMMUNITY CENTER		DATE 5/1/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 7/31/2015
LOCATION 670 COLTON AV, COLTON, CA 92324			INSPECTOR John Babalola	
MAILING ADDRESS 670 COLTON AV, COLTON, CA 92324			IDENTIFIER: Pool	
			SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN 10:54 AM	TIME OUT 11:49 AM	FACILITY ID FA0001922	RELATED ID PR0015631	PE 3620
			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
			ACTION: 01 - NO FURTHER ACTION REQUIRED	




**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**100**  
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	350
required flow (gpm)	450
volume (gal)	No Data
area (sq ft)	No Data
occupancy	300

**36K506 Water Quality – Critical – Water pH 7.2 to 7.8** ⚠ CRITICAL ⚠

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	Inspector Comments: The pH level is observed at 8.0. Maintain the pH between 7.2 and 7.8. Ideal pH is 7.4 - 7.6.
	Not In Compliance	
	Violation Reference - HSC - 65530	Note: Correction is being made.

Violation Description: The pool operator shall maintain public pool water at pH 7.2 to 7.8.

**36K504 Water Quality – Non-Critical – Disinfectant level low**

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	Inspector Comments: Observed the free chlorine level at 0.8 ppm. Provide at least 2.0 ppm.
	Not In Compliance	
	Violation Reference - HSC - 65529	Note: Correction is being made.

Violation Description: The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Signature(s) of Acknowledgement**

NAME: Brandon Parra  
TITLE: Recreation Coordinator

Total # of Images: 0