



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME BUNGALOWS THE		DATE 4/17/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2015
LOCATION 33800 CHAPMAN HEIGHTS RD, YUCAIPA, CA 92399			INSPECTOR Tia Wilson	
MAILING ADDRESS 33800 CHAPMAN HEIGHTS RD, YUCAIPA, CA 92399			IDENTIFIER: Pool	
<input checked="" type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT			SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN 9:56 AM	TIME OUT 10:39 AM	FACILITY ID FA0014687	RELATED ID PR0019398	PE 3620
			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
			ACTION: 01 - NO FURTHER ACTION REQUIRED	




RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

92
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	71
volume (gal)	25,500
area (sq ft)	800
occupancy	40

36K402 Water Quality - Critical - Lack of Disinfectant ⚠️ CRITICAL ⚠️

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed free chlorine concentration measuring 0.92 ppm. Observed cyanuric acid concentration measuring 105 ppm. Raise free chlorine concentration to at least 1.5 ppm and below 10 ppm. Observed pool contractor apply 2 gallons sodium hypochlorite to pool and consequent chlorine concentration measuring 3.42 ppm.
	Complied on 4/17/2015	
	Violation Reference - CCR - 65529	

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

36K418 Water Quality - Cyanurates

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed cyanuric acid concentration measuring 105 ppm. Maintain cyanuric acid level below 100 ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: The cyanuric acid concentration in any pool shall not exceed 100 ppm.

36K448 Equipment - Flow Meter

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed flowmeter not functioning. Provide functioning flowmeter.
	Not In Compliance	
	Violation Reference - CCR - 3125B	

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

Overall Inspection Comments

Measured observations:
pH 7.7
Free chlorine 0.92 ppm
Cyanuric Acid 105 ppm

Observed final free chlorine concentration measuring 3.42 ppm.

Signature(s) of Acknowledgement



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME BUNGALOWS THE	DATE 4/17/2015
LOCATION 33800 CHAPMAN HEIGHTS RD, YUCAIPA, CA 92399	INSPECTOR Tia Wilson

A handwritten signature in blue ink, appearing to read "Maureen Davis".

NAME: Maureen Davis
TITLE: Manager

Total # of Images: 0