



Public Health
Environmental Health Services




www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME CALIFORNIA ATHLETIC CLUB		DATE 6/16/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 7/31/2015
LOCATION 9120 HAVEN , RANCHO CUCAMONGA, CA 91730			INSPECTOR Nick Thalasinos	
MAILING ADDRESS 9120 HAVEN , RANCHO CUCAMONGA, CA 91730			IDENTIFIER: Spa	
<input checked="" type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT			SERVICE: 008 - INSPECTION - ATTEMPTED	
TIME IN 1:15 PM	TIME OUT 1:45 PM	FACILITY ID FA0005871	RELATED ID PR0015016	PE 3622
RESULT: 00 - NOT APPLICABLE				
ACTION: 00 - NOT APPLICABLE				

RECREATIONAL HEALTH - Public Pool - Initial Spa at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	123
volume (gal)	3,702
area (sq ft)	165
occupancy	19

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K996 Attempted Inspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: _____
	Not In Compliance	
	Violation Reference - HSC	

Description: An inspection was attempted today. Another inspection will be attempted at a later date.

Overall Inspection Comments

This facility is out of business, new owners need to apply for a change of ownership.

Signature(s) of Acknowledgement

NAME:
TITLE:
Total # of Images: 0