



Public Health

Environmental Health Services

RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT

FACILITY NAME LA PIZZA LOCA 77		DATE 8/6/2015	REINSPECTION DATE 8/20/2015	PERMIT EXPIRATION 8/31/2015
LOCATION 1436 S EUCLID AV, ONTARIO, CA 91762			INSPECTOR Veronica Martinez	
MAILING ADDRESS 9550 FIRESTONE BL UNIT 101, DOWNEY CA 90241			IDENTIFIER: Food	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
TIME IN 10:07 AM	TIME OUT 10:55 AM	FACILITY ID FA0009824	RELATED ID PR0000486	PE 1620
			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU	
			ACTION: 13 - PERMIT SUSPENDE / FACILITY CLOSED	

RETAIL FOOD PROTECTION - Public Eating PI (0-24 Seats)

16K994 Reinspection

Compliance Date: Not Specified

Not In Compliance

Reference - HSC

Inspector Comments: A reinspection was conducted today in regard to the facility observed unable to provide hot water at a minimum temperature of 120 F during the last routine inspection. Provide hot water to at least one sink in facility at a minimum temperature of 120 F.

Upon inspection, maximum water temperature observed measuring 81.5 F. The facility is hereby ordered closed. Contact Division of Environmental Health Services (DEHS) at 1(800) 442-2283 to request a re-inspection. Do not open unless authorized by DEHS. Non-compliance may result in future charged inspection at \$245.00 per hour.

Description: Reinspection conducted at this time to determine compliance from prior inspection.

16K054 Permit Suspension



Compliance Date: Not Specified

Not In Compliance

Violation Reference - HSC - 114409, 114405

Inspector Comments: The permit is suspended and facility hereby ordered closed due to lack of hot water observed during reinspection.

Violation Description: If an imminent health hazard is found, an enforcement officer may temporarily suspend the permit and order the food facility immediately closed. (114409, 114405)

16K021 Hot and cold water available

Compliance Date: Not Specified

Not In Compliance

Violation Reference - HSC - 113953(c), 114099.2(b)

Inspector Comments: Observed facility unable to provide hot water at a minimum temperature of 120 F at the time of reinspection; maximum water temperature observed measuring 81.5 F. The facility is hereby ordered closed. Provide hot water to at least one sink in facility at a minimum temperature of 120 F.

Violation Description: An adequate, protected, pressurized, potable supply of hot water and cold water shall be provided at all times. (113953(c), 114099.2(b) 114101(a), 114189, 114192, 114192.1, 114195)

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME: Nohani Garcia

TITLE:

Total # of Images: 0