



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME IRIS GARDEN		DATE 5/1/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 7/31/2015
LOCATION 12253 TULIP LN, YUCAIPA, CA 92399			INSPECTOR Tia Wilson	
MAILING ADDRESS 195 N EUCLID AV STE 100, UPLAND CA 91786			IDENTIFIER: Spa	
			SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN 3:04 PM	TIME OUT 3:49 PM	FACILITY ID FA0016374	RELATED ID PR0021805	PE 3623
			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
			ACTION: 01 - NO FURTHER ACTION REQUIRED	




RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

94
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	102.2
observed flow (gpm)	100
required flow (gpm)	No Data
volume (gal)	65,000
area (sq ft)	1,500
occupancy	No Data

36K416 Water Quality - Non-Critical - Clarity

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed water cloudy but main drains visible. Maintain water clear.
	Not In Compliance	
	Violation Reference - CCR - 65527, 65543	

Violation Description: The recirculation and purification system shall be operated and maintained so as to keep the pool water clean and clear. Under no circumstances shall the pool be used if the main drain is not clearly visible from the deck. The water of every wading pool shall be kept sufficiently clear so that the bottom of the wading pool will be visible at all times.

36K427 Safety - Safety Signs

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed incorrect wording for Warning sign and nearest emergency services number missing from Emergency sign.
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME IRIS GARDEN	DATE 5/1/2015
LOCATION 12253 TULIP LN, YUCAIPA, CA 92399	INSPECTOR Tia Wilson

36K458 Maintenance - Test Kit/Daily Records

POINTS
2

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - CCR - 65523,
 65529

Inspector Comments: Observed OTO test kit in pump area.
 OTO test kit can only test for total chlorine (free and combined chlorine). Obtain test kit capable of testing free chlorine residual.

Observed entries missing from daily record.
 Ensure readings and procedures are conducted and recorded daily.

Violation Description: Appropriate test kits for measuring the pH, concentration of the disinfectant, and, when used, concentration of cyanuric acid shall be provided at each pool. The test kit shall be capable of testing for free chlorine residual.

The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.

36K594 Supervision - Pool operator

POINTS
NA

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - HSC - 65521

Inspector Comments: Observed pool supervisor not available.
 Ensure pool supervisor is available.

Violation Description: Every public pool shall be under the supervision of a pool operator.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME: Signature not available
 TITLE:

Total # of Images: 0