



**Public Health**  
Environmental Health Services

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME VILLAGE OAKS APARTMENTS		DATE 6/16/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2015
LOCATION 15773 HIGH KNOLL DR, CHINO HILLS, CA 91709			INSPECTOR Casey Salazar	
MAILING ADDRESS 15773 HIGH KNOLL DR, CHINO HILLS, CA 91709			IDENTIFIER: Pool - South	
			SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN 11:00 AM	TIME OUT 11:45 AM	FACILITY ID FA0005109	RELATED ID PR0015982	PE 3621
			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
			ACTION: 01 - NO FURTHER ACTION REQUIRED	

**RECREATIONAL HEALTH - Public Pool - Additional Pool at Facility**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$ 4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**93**

SCORE

Ideal
In Compliance
Not in Compliance



temperature (°F)	80.4
observed flow (gpm)	65
required flow (gpm)	52
volume (gal)	18,720
area (sq ft)	602
occupancy	30

**IMPORTANT: Replacement of Suction Outlet Covers**

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K540 Enclosure – Critical – Gates and doors self-closing and self-latching**



POINTS <b>5</b>	Compliance Date: Not Specified	Inspector Comments: Observed gate near fitness room not self latching. Ensure all gates can self-close and self-latch. Repair/replace gate. Corrective action: Gate has been zip-tied.
	Not In Compliance	
	Violation Reference - CCR - 3119B	

**Violation Description:** Gates and doors shall be equipped with self-closing and self-latching devices. Gates and doors shall be capable of being locked during times when the pool is closed. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. The pool enclosure shall have at least one means of egress without a key for emergency purposes. The enclosure shall be constructed so that all persons will be required to pass through common pool enclosure gates or doors in order to gain access to the pool area. All gates and doors exiting the pool area shall open into a public area or a walkway accessible by all patrons of the pool.

**36K576 Maintenance – Operation/Incident records**

POINTS <b>1</b>	Compliance Date: Not Specified	Inspector Comments: Observed no records at pool site. Maintain daily records at pool site.
	Not In Compliance	
	Violation Reference - HSC - 65523	

**Violation Description:** The pool operator shall maintain a written daily record of all test results, equipment readings, calibrations, and corrective action taken at the public pool site. [This includes daily records of pH, disinfectant level, and water temperature. If used, cyanuric acid concentration shall be tested monthly.]

If a fecal, vomit, blood contamination, near-drowning, or drowning incident occurs in a pool, the pool operator shall record the incident in accordance with the requirements of [Health and Safety Code] section 65546 and shall identify the affected public pool in the incident record if there is more than one pool at the public pool site. This record shall be maintained at the public pool site.

**36K582 Maintenance - Public pool site maintenance**

POINTS <b>1</b>	Compliance Date: Not Specified	Inspector Comments: Observed one drinking fountain not working. Repair/replace water fountain. Observed sand filter media from a broken bag inside pump room. Ensure pump room is well maintained.
	Not In Compliance	
	Violation Reference - HSC - 65535	

**Violation Description:** The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

**Overall Inspection Comments**

Observed men's restroom roped off. Ensure there are restrooms available for each sex.



**Public Health**  
Environmental Health Services

[www.SBCounty.gov](http://www.SBCounty.gov)

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME VILLAGE OAKS APARTMENTS	DATE 6/16/2015
LOCATION 15773 HIGH KNOLL DR, CHINO HILLS, CA 91709	INSPECTOR Casey Salazar

**Signature(s) of Acknowledgement**

NAME: Amber  
TITLE: PIC

Total # of Images: 0