



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME MULBERRY PLACE		REINSPECTION DATE Not Specified	INSPECTOR Mark Williams	DATE 9/20/2016
LOCATION ARROW ROUTE / VINEYARD, RANCHO CUCAMONGA, CA 91730		PERMIT EXPIRATION 8/31/2017	IDENTIFIER: Pool SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
TIME IN 11:00 AM	TIME OUT 11:22 AM	FACILITY ID FA0006099	RELATED ID PR0014903	PE 3620
		RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED ACTION: 15 - PERMIT REINSTATED / FACILITY RE-OPEN		


RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	45
volume (gal)	22,000
area (sq ft)	740
occupancy	37

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K992 Permit Reinstatement

POINTS NA	Compliance Date: Not Specified	Inspector Comments: This health permit was re-instated this date.
	Not In Compliance	
	Violation Reference - HSC	

Description: The health permit to operate is hereby reinstated and facility may open.

36K994 Reinspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: This re-inspection was conducted at the request of the pool operator. This pool was closed and the health permit suspended on 9-16-2016 due to a high chlorine content over 10 ppm. On this date the chlorine was observed in the pool @ 7.89 ppm and the health permit for this pool was reinstated this date. All pool / spa closure signs were removed this date.
	Not In Compliance	
	Violation Reference - HSC	

Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

Note-Pool closure sign removed from gate this date.
This inspection was conducted with the pool maintenance person present.

Signature(s) of Acknowledgement

NAME: Daniel Magruder
TITLE: Pool Maintenance

Total # of Images: 0