



Public Health
Environmental Health Services




www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME LOCH LEVEN CHRISTIAN CAMP & CONFERENCE CENTER		DATE 6/29/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 12/31/2015
LOCATION 8171 MOUNTAIN HOME CREEK RD, MENTONE, CA 92359			INSPECTOR Tia Wilson	
MAILING ADDRESS 36910 MILLCREEK RD, MENTONE CA 92359			IDENTIFIER: Pool	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
TIME IN 9:54 AM	TIME OUT 10:28 AM	FACILITY ID FA0006918	RELATED ID PR0006543	PE 3620
RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED				
ACTION: 15 - PERMIT REINSTATED / FACILITY RE-OPEN				

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	85
volume (gal)	41,010
area (sq ft)	1,040
occupancy	52

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K992 Permit Reinstatement

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Observed free chlorine measuring 4.0 ppm. Facility in compliance. Pool reopened.
	Not In Compliance	
	Violation Reference - HSC	

Description: The health permit to operate is hereby reinstated and facility may open.

36K994 Reinspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: A reinspection was conducted regarding lack of chlorine detected during the last inspection.
	Not In Compliance	
	Violation Reference - HSC	

Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

Facility in compliance. Pool reopened.

Signature(s) of Acknowledgement

NAME: Sloan Hamilton
TITLE: Director

Total # of Images: 0