



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME SUN TREE APARTMENTS		REINSPECTION DATE Not Specified		INSPECTOR Helen Godinez	DATE 6/6/2016
LOCATION 1551 W RIALTO AV, FONTANA, CA 92335				PERMIT EXPIRATION 3/31/2017	IDENTIFIER: Pool
TIME IN 9:34 AM	TIME OUT 10:39 AM	FACILITY ID FA0005307	RELATED ID PR0015107	PE 3620	SERVICE: 001 - INSPECTION - ROUTINE RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU ACTION: 03 - REINSPECTION REQUIRED

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

89
SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	60
volume (gal)	21,500
area (sq ft)	690
occupancy	24

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K514 Water Quality – Critical – Water clarity ⚠️ CRITICAL ⚠️

POINTS 5	Compliance Date: Not Specified	Inspector Comments: Observed the pool to have cloudy green pool water, not able to see the floor of the pool. Operator stated pump is out and put a "closed Sign" on the main pool gate. Ensure pool water remains clear while in use.
	Not In Compliance	
	Violation Reference - HSC - 65527	

Violation Description: The pool operator shall maintain clear pool water while the public pool is in use. The pool operator shall close the public pool if the bottom of the pool at the maximum depth is not clearly visible from the deck. The pool operator shall not reopen the public pool for use until the pool water is clean and clear, and the bottom of the pool at the maximum depth is clearly visible from the deck. If the bottom of the pool is not visible 48 hours following inspection and closure by the enforcing agent, the enforcing agent may order the pool drained.

36K544 Equipment – Critical – Water treatment system operation ⚠️ CRITICAL ⚠️

POINTS 5	Compliance Date: Not Specified	Inspector Comments: Observed the recirculation system to the pool is non functional. The operator has voluntarily posted a "closed" sign due to pump breaking. The sign posted on the main gate Repair or replace with an approved recirculation system to ensure proper function to maintain the pool facility. Contact Environmental Health Plan Check when making recirculation equipment changes.
	Not In Compliance	
	Violation Reference - HSC - 65525	

Violation Description: The pool operator shall operate pumps, filters, disinfectant and chemical feeders, flow indicators, gauges, recirculation systems, disinfection systems, and all parts of the water treatment system whenever the public pool is available for use, and at such additional times and periods as may be necessary to maintain clean pool water, clear pool water, and the disinfection standards required in section 65529 [Health and Safety Code].



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME SUN TREE APARTMENTS	DATE 6/6/2016
LOCATION 1551 W RIALTO AV, FONTANA, CA 92335	INSPECTOR Helen Godinez

36K527 Safety – Safety signs

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed the safety signs missing the facility name, address and the nearest emergency telephone number. Ensure the facility name and address are clearly posted in at least one (1) inch letter on the safety sign, also include the telephone number to the nearest emergency facility.
	Not In Compliance Violation Reference - CCR - 3120B	

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) ""NO DIVING"" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, ""WARNING: NO LIFEGUARD ON DUTY."" The sign also shall state in letters at least 1 inch high, ""Children under the age of 14 shall not use pool without a parent or adult guardian in attendance.""
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with ""CAUTION"" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, ""NO USE OF POOL ALLOWED AFTER DARK.""
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, ""KEEP GATE CLOSED"" or ""KEEP DOOR CLOSED"".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, ""CAUTION: WATER IS RECIRCULATED. DO NOT DRINK.""

Overall Inspection Comments

Operator self closed the pool facility. Re-inspection for Thursday 06-09-16.

Signature(s) of Acknowledgement

NAME: jacqueline guerra
TITLE:

Total # of Images: 0