



**Public Health**  
**Environmental Health Services**

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>PACIFIC HIGH SCHOOL</b>		DATE <b>8/21/2015</b>	REINSPECTION DATE <b>Next Routine</b>	PERMIT EXPIRATION
LOCATION <b>1020 PACIFIC ST, SAN BERNARDINO, CA 92404</b>			INSPECTOR <b>Chris Nwadike</b>	
MAILING ADDRESS <b>1020 PACIFIC ST, SAN BERNARDINO, CA 92404</b>			IDENTIFIER: Shallow Pool	
TIME IN <b>1:08 PM</b>			SERVICE: 001 - INSPECTION - ROUTINE	
TIME OUT <b>2:01 PM</b>			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
FACILITY ID <b>FA0004188</b>			ACTION: 01 - NO FURTHER ACTION REQUIRED	
RELATED ID <b>PR0013903</b>			PE <b>3603</b>	

**RECREATIONAL HEALTH - Public School Pool / Spa**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**97**  
SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	81.0
observed flow (gpm)	340
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**IMPORTANT: Replacement of Suction Outlet Covers**  
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K504 Water Quality – Non-Critical – Disinfectant level low**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed chlorine level at 1.32ppm. Maintain between 2.0 and 10.0ppm.
	Not In Compliance	
	Violation Reference - HSC - 65529	

**Violation Description:** The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

**36K554 Equipment - Pressure/Vacuum gauge requirements**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed no influent gauge. Install the influent gauge.
	Not In Compliance	
	Violation Reference - CCR 24 - 3125B.2	

**Violation Description:** A pressure and vacuum gauge shall be provided for each pump system. Each gauge shall have a scale range approximately 1 ¼ times the maximum anticipated working pressure or vacuum and shall be accurate within 2 percent of scale. The pressure gauge located on the filter shall be marked with the clean start up pressure reading.

**36K582 Maintenance - Public pool site maintenance**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed loose hand rails. Tighten the loose hand rails.
	Not In Compliance	
	Violation Reference - HSC - 65535	

**Violation Description:** The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.



**Public Health**  
Environmental Health Services

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME PACIFIC HIGH SCHOOL	DATE 8/21/2015
LOCATION 1020 PACIFIC ST, SAN BERNARDINO, CA 92404	INSPECTOR Chris Nwadike

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Signature(s) of Acknowledgement**

NAME:  
TITLE:

Total # of Images: 0