



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME BORDEAUX SB LLC		DATE 5/7/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 3/31/2016
LOCATION 1025 N TIPPECANOE AV, SAN BERNARDINO, CA 92410			INSPECTOR Chris Nwadike	
MAILING ADDRESS PO BOX 7621, REDLANDS CA 92375			IDENTIFIER: Pool	
			SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN 2:56 PM	TIME OUT 4:03 PM	FACILITY ID FA0004023	RELATED ID PR0015910	PE 3620
			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
			ACTION: 01 - NO FURTHER ACTION REQUIRED	




RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

96
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	70.0
observed flow (gpm)	35
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:
1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump
Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K508 Water Quality – Non-Critical – Water pH 7.2 to 7.8

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed pH level at 7.1.
	Not In Compliance	Maintain pH between 7.2 and 8.0
	Violation Reference - HSC - 65530	

Violation Description: The pool operator shall maintain public pool water at pH 7.2 to 7.8.

36K518 Water Quality – Cyanuric acid concentration

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed the cyanuric acid at more than 109.0ppm.
	Not In Compliance	Maintain cyanuric acid level below 100.0ppm (under 50.0ppm preferred).
	Violation Reference - HSC - 65530	

Violation Description: The maximum concentration of cyanuric acid in public pool water shall not exceed 100.0 ppm.

36K556 Equipment – Plumbing labeled

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed no labels/markings on the piping in the equipment/pump area showing the direction of water flow/recirculation.
	Not In Compliance	The direction of water flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.
	Violation Reference - CCR 24 - 3120B	

Violation Description: The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area. Where the recirculation equipment for more than one pool is located on site, the equipment shall be marked as to which pool the system serves. Valves and plumbing lines shall be labeled clearly with the source or destination descriptions.

36K562 Skimmers – Pool skimming systems

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed no weir gate to the skimmer.
	Not In Compliance	Provide the weir gate.
	Violation Reference - CCR - 3136B	

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 100 percent of the flow rate. Each surface skimmer shall comply with the requirements in accordance with section 3136B, Title 24, California Code of Regulations.

Overall Inspection Comments



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME BORDEAUX SB LLC	DATE 5/7/2015
LOCATION 1025 N TIPPECANOE AV, SAN BERNARDINO, CA 92410	INSPECTOR Chris Nwadike

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME:
TITLE:

Total # of Images: 0