



**Public Health**  
Environmental Health Services




www.SBCounty.gov

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME CREEKSIDE APARTMENTS		DATE 6/5/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 10/31/2015
LOCATION 495 E 3RD ST, SAN BERNARDINO, CA 92410			INSPECTOR Chris Nwadike	
MAILING ADDRESS 495 E 3RD ST, SAN BERNARDINO, CA 92410			IDENTIFIER: Office Spa	
<input checked="" type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
TIME IN 11:57 AM	TIME OUT 12:51 PM	FACILITY ID FA0006348	RELATED ID PR0013866	PE 3623
RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE				
ACTION: 01 - NO FURTHER ACTION REQUIRED				

**RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility**

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**IMPORTANT: Replacement of Suction Outlet Covers**

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K504 Water Quality – Non-Critical – Disinfectant level low**

**POINTS**  
**1**

Compliance Date: Not Specified  
Not In Compliance  
Violation Reference - HSC - 65529

Inspector Comments: Chlorine level has been corrected to 6.0ppm.  
Spa remains open for use.

**Violation Description:** The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Signature(s) of Acknowledgement**

NAME:  
TITLE:

Total # of Images: 0