



Public Health
Environmental Health Services




www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME RANCHO MONTE VISTA MOBILEHOME PARK		DATE 6/11/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2015
LOCATION 15050 MONTE VISTA AV, CHINO HILLS, CA 91710			INSPECTOR Casey Salazar	
MAILING ADDRESS 1801 E EDINGER AV STE 230, SANTA ANA CA 92705			IDENTIFIER: Wading Pool	
TIME IN 4:10 PM			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
TIME OUT 4:33 PM			RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED	
FACILITY ID FA0006998			ACTION: 15 - PERMIT REINSTATED / FACILITY RE-OPEN	
RELATED ID PR0014037			PE 3621	

RECREATIONAL HEALTH - Public Pool - Additional Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	15
volume (gal)	890
area (sq ft)	95
occupancy	9

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K992 Permit Reinstatement

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Facility has brought free chlorine levels to required concentration and wading pool has been opened.
	Not In Compliance	
	Violation Reference - HSC	

Description: The health permit to operate is hereby reinstated and facility may open.

36K994 Reinspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Observed chlorine levels at 5.27 ppm.
	Not In Compliance	
	Violation Reference - HSC	

Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

Wading pool opened.

Signature(s) of Acknowledgement

NAME:
TITLE: PIC

Total # of Images: 0