



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME BONANZA MOBILE ESTATES		REINSPECTION DATE Not Specified	INSPECTOR Yvette Velasco	DATE 10/5/2015
LOCATION 13645 5TH ST B, YUCAIPA, CA 92399		PERMIT EXPIRATION	IDENTIFIER: None	
TIME IN 12:22 PM	TIME OUT 12:38 PM	FACILITY ID FA0007228	RELATED ID CO0052044	PE 3620
SERVICE: 004 - COMPLAINT - INITIAL RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE ACTION: 01 - NO FURTHER ACTION REQUIRED				




RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	80.0
observed flow (gpm)	45
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K999 Complaint Inspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: On 9/28/15 the Division of Environmental Health received a complaint. Complainant stated that the pool is dirty and murky. Observed no person in charge on site. Observed good clarity in the pool and no difficulty viewing the bottom drain from deck area. Observed the following violations.
	Not In Compliance	
	Violation Reference - HSC	

Description: A complaint report has been received by Environmental Health.

36K504 Water Quality – Non-Critical – Disinfectant level low

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed free chlorine levels in the pool at 01ppm. Ensure to maintain free chlorine at 2.0-10.0ppm with cyanuric acid.
	Not In Compliance	
	Violation Reference - HSC - 65529	

Violation Description: The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

36K518 Water Quality – Cyanuric acid concentration

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed cyanuric acid levels high. Ensure to maintain cyanuric acid levels in the pool below 100.0ppm.
	Not In Compliance	
	Violation Reference - HSC - 65530	

Violation Description: The maximum concentration of cyanuric acid in public pool water shall not exceed 100.0 ppm.

Overall Inspection Comments

No summary comments have been made for this inspection.



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

<small>FACILITY NAME</small> BONANZA MOBILE ESTATES	<small>DATE</small> 10/5/2015
<small>LOCATION</small> 13645 5TH ST B, YUCAIPA, CA 92399	<small>INSPECTOR</small> Yvette Velasco

Signature(s) of Acknowledgement

NAME:

TITLE:

Total # of Images: 0