





RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME PRINCETON VILLAGE			REINSPECTION DATE Not Specified		INSPECTOR Nicole Walker	DATE 7/16/2015
LOCATION 1141 W PRINCETON , ONTARIO, CA 91762			PERMIT EXPIRATION 6/30/2016		IDENTIFIER: Pool	
TIME IN 12:30 PM	TIME OUT 12:37 PM	FACILITY ID FA0008510	RELATED ID PR0014478	PE 3620	SERVICE: 008 - INSPECTION - ATTEMPTED	
					RESULT: 00 - NOT APPLICABLE	
					ACTION: 00 - NOT APPLICABLE	

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	48
volume (gal)	17,325
area (sq ft)	420
occupancy	21

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K996 Attempted Inspection

POINTS
NA

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments: An inspection was attempted today.

Description: An inspection was attempted today. Another inspection will be attempted at a later date.

Overall Inspection Comments

An inspection was attempted today.

Signature(s) of Acknowledgement

NAME:
TITLE:

Total # of Images: 0