



RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT

FACILITY NAME QUICK STOP		REINSPECTION DATE Not Specified		INSPECTOR Guy Surber	DATE 7/6/2021
LOCATION 10120 25TH ST, RANCHO CUCAMONGA, CA 91730				PERMIT EXPIRATION 10/31/2021	IDENTIFIER: None
TIME IN 11:31 AM	TIME OUT 11:45 AM	FACILITY ID FA0007692	RELATED ID PR0022470	PE 1620	SERVICE: 006 - FIELD CONSULTATION RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED

RETAIL FOOD PROTECTION - Public Eating PI (0-24 Seats)

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

16K054 Permit Suspension



Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC - 114409, 114405

Inspector Comments: Permit suspended for restaurant at Quick Stop market Deli in Rancho Cucamonga because handwashing sink and three compartment sink did not have cold water and hot water was too hot for handwashing. Facility closure sign posted in restaurant area. Contact San Bernardino County Environmental Health Services at (800)442-2283 for a reinspection when repairs are complete. These sinks must be verified to have hot water that is a minimum of 120F and cold water prior to reopening.

Violation Description: If an imminent health hazard is found, an enforcement officer may temporarily suspend the permit and order the food facility immediately closed. (114409, 114405)

16K041 Plumbing; proper backflow devices

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC - 114171, 114189.1

Inspector Comments: Observed that three compartment sink and handwashing sink in restaurant did not have cold water and that hot water was too hot for handwashing.

Repair these faucets so that they produce hot water at a minimum of 120F and cold water. Ensure that each faucet has a handle for the hot and the cold water.

Permit suspended for restaurant at Quick Stop market Deli in Rancho Cucamonga because handwashing sink and three compartment sink did not have cold water and hot water was too hot for handwashing. Facility closure sign posted in restaurant area. Contact San Bernardino County Environmental Health Services at (800)442-2283 for a reinspection when repairs are complete. These sinks must be verified to have hot water that is a minimum of 120F and cold water prior to reopening.

Violation Description: The potable water supply shall be protected with a backflow or back siphonage protection device, as required by applicable plumbing codes. (114192) All plumbing and plumbing fixtures shall be installed in compliance with local plumbing ordinances, shall be maintained so as to prevent any contamination, and shall be kept clean, fully operative, and in good repair. Any hose used for conveying potable water shall be of approved materials, labeled, properly stored, and used for no other purpose. (114171, 114189.1, 114190, 114193, 114193.1, 114199, 114201, 114269)

Overall Inspection Comments

Permit suspended at food facility because cold water not functioning at handwashing sink and three compartment sink.

FREE Classes to L.E.A.R.N!

Liaison Education And Risk Network (L.E.A.R.N.) is a FREE class based on the fundamentals of Active Managerial Control and the Centers for Disease Control and Prevention's five risk factors that lead to foodborne illnesses. Find out when the next L.E.A.R.N. class is by checking our [calendar](#).

Signature(s) of Acknowledgement

No Sig.

NAME: Karen Solanki
TITLE:

Total # of Images: 0