



Public Health
Environmental Health Services



www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME CELAMONTE			DATE 8/5/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2016
LOCATION 17871 SHADY VIEW DR, CHINO HILLS, CA 91709				INSPECTOR Casey Salazar	
MAILING ADDRESS 25531 COMMERCENTER DR STE 100, LAKE FOREST CA 92630			<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT IDENTIFIER: Pool SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE ACTION: 15 - PERMIT REINSTATED / FACILITY RE-OPEN		
TIME IN 9:35 AM	TIME OUT 9:45 AM	FACILITY ID FA0015564	RELATED ID PR0020692	PE 3620	

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	93
volume (gal)	33,468
area (sq ft)	1,050
occupancy	53

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K992 Permit Reinstatement

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Pool has been opened by Environmental Health.
	Not In Compliance	
	Violation Reference - HSC	

Description: The health permit to operate is hereby reinstated and facility may open.

36K994 Reinspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: A follow up inspection was conducted regarding high chlorine levels observed during last routine inspection. During inspection observed chlorine levels at 0.41 ppm. Maintain free chlorine between 1-10 ppm.
	Not In Compliance	
	Violation Reference - HSC	

Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

Pool has been opened by Environmental Health.

Signature(s) of Acknowledgement

NAME: Signature not available
TITLE: PIC

Total # of Images: 0