



Public Health
Environmental Health Services



www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME DESERT VISTA VILLAGE		DATE 6/24/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 7/31/2015
LOCATION 7345 PALM AV, YUCCA VALLEY, CA 92284			INSPECTOR Marilyn Krichbaum	
MAILING ADDRESS PO BOX 90250, HENDERSON NV 89009			IDENTIFIER: Spa	
TIME IN 10:07 AM			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
TIME OUT 10:35 AM			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
FACILITY ID FA0017228			ACTION: 15 - PERMIT REINSTATED / FACILITY RE-OPEN	
RELATED ID PR0023256			PE 3623	

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K994 Reinspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Observed a ph a high ph level of 8.0. Lower the ph level so that it is 7.2-7.8.
	Not In Compliance	Pool can be reopened. Health permit is reinstated.
	Violation Reference - HSC	

Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME: Ruth Hatfield
TITLE:

Total # of Images: 0