



**Public Health**  
Environmental Health Services

www.SBCounty.gov

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME 24 HOUR FITNESS CLUB 180		DATE 6/10/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 3/31/2016
LOCATION 4200 CHINO HILLS PKWY 780, CHINO HILLS, CA 91709			INSPECTOR Casey Salazar	
MAILING ADDRESS PO BOX 2409, CARLSBAD CA 92018			IDENTIFIER: Spa	
			SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN 3:30 PM	TIME OUT 4:21 PM	FACILITY ID FA0014012	RELATED ID PR0018514	PE 3623
			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
			ACTION: 01 - NO FURTHER ACTION REQUIRED	

**RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**98**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	101.2
observed flow (gpm)	85
required flow (gpm)	90
volume (gal)	2,700
area (sq ft)	140
occupancy	14

**IMPORTANT: Replacement of Suction Outlet Covers**

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K527 Safety – Safety signs**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified
	Not In Compliance
	Violation Reference - CCR - 3120B

**Inspector Comments:** Observed the following signs missing from enclosure:  
 -Illustrated diagram with text of artificial respiration and CPR procedures.  
 -Number of nearest emergency services  
 -Name and address of facility  
 -Diarrhea notice

Provide required signs.

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

**36K562 Skimmers - Pool skimming systems**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified
	Not In Compliance
	Violation Reference - CCR - 3136B

**Inspector Comments:** Observed both weir gates missing from skimmers. Provide a weir gate.

**Violation Description:** The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 100 percent of the flow rate. Each surface skimmer shall comply with the requirements in accordance with section 3136B, Title 24, California Code of Regulations.



**Public Health**  
**Environmental Health Services**

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME 24 HOUR FITNESS CLUB 180	DATE 6/10/2015
LOCATION 4200 CHINO HILLS PKWY 780, CHINO HILLS, CA 91709	INSPECTOR Casey Salazar

**Overall Inspection Comments**

Light switch to manually operate pool/spa lights were unable to be located. Per staff, personnel who would know is not available. Unable to test GFCI. Ensure GFCI is fully operational by next inspection.

**Signature(s) of Acknowledgement**

NAME: Anton  
TITLE: PIC

Total # of Images: 0