



**Public Health**  
**Environmental Health Services**

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>BELL GARDEN APARTMENTS</b>		DATE <b>7/30/2015</b>	REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>6/30/2016</b>
LOCATION <b>2050 S EUCLID, ONTARIO, CA 91761</b>			INSPECTOR <b>Veronica Martinez</b>	
MAILING ADDRESS <b>PO BOX 9037, BREA CA 92622</b>			IDENTIFIER: Pool	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN <b>4:16 PM</b>	TIME OUT <b>5:00 PM</b>	FACILITY ID <b>FA0005603</b>	RELATED ID <b>PR0015017</b>	PE <b>3620</b>
			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU	
			ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED	

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.




**84**

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**IMPORTANT: Replacement of Suction Outlet Covers**  
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K502 Water Quality - Critical – Disinfectant level** ⚠️ CRITICAL ⚠️

<b>POINTS</b> <b>5</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed free chlorine residual measuring above 11.0 ppm. Maintain free chlorine residual between 2.0 ppm and 10.0 ppm in the presence of cyanuric acid. The pool is hereby closed.
	<b>Not In Compliance</b>	
	Violation Reference - HSC - 65529	

**Violation Description:** The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

A spray ground and water features with an ultraviolet light disinfection system shall be disinfected continuously at a minimum of 40 mJ/cm2 by the ultraviolet light disinfection units while the spray ground and water features are in use. If the ultraviolet dosage rate drops below 40 mJ/cm2 the operator shall close the spray ground and water features.

**36K522 Safety – Critical – Unsafe or hazardous conditions** ⚠️ CRITICAL ⚠️

<b>POINTS</b> <b>5</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed loose equalizer suction outlet cover separated from wall approximately 2 inches. Repair or replace within 24 hours. The pool is hereby closed.
	<b>Not In Compliance</b>	
	Violation Reference - HSC - 65545	

**Violation Description:** A public pool that is maintained or operated in a manner that creates an unhealthful, unsafe, or unsanitary condition may be closed by the enforcing agent.



## Public Health

### Environmental Health Services

### RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME <b>BELL GARDEN APARTMENTS</b>	DATE <b>7/30/2015</b>
LOCATION <b>2050 S EUCLID , ONTARIO, CA 91761</b>	INSPECTOR <b>Veronica Martinez</b>

#### IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

#### 36K540 Enclosure – Critical – Gates and doors self-closing and self-latching



<b>POINTS</b> <b>5</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed entry gate propped open with brick. Maintain gate securely closed.  Brick removed and gate securely closed.
	Not In Compliance	
	Violation Reference - CCR - 3119B	

**Violation Description:** Gates and doors shall be equipped with self-closing and self-latching devices. Gates and doors shall be capable of being locked during times when the pool is closed. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. The pool enclosure shall have at least one means of egress without a key for emergency purposes. The enclosure shall be constructed so that all persons will be required to pass through common pool enclosure gates or doors in order to gain access to the pool area. All gates and doors exiting the pool area shall open into a public area or a walkway accessible by all patrons of the pool.

#### 36K582 Maintenance - Public pool site maintenance

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed five chlorine tablets in skimmer basket. Remove and discontinue practice. Ensure chemical disinfectant feeder is working properly.
	Not In Compliance	
	Violation Reference - HSC - 65535	

**Violation Description:** The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

#### 36K596 Permit - Public Pool Closure

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> The permit to operate is hereby suspended and pool is ordered closed. Contact Division of Environmental Health Services (DEHS) at 1(800) 442-2283 to request a re-inspection to open pool. Do not open pool for use unless authorized by DEHS. Non-compliance may result in future charged inspection at \$245.00 per hour.
	Not In Compliance	
	Violation Reference - HSC - 65545	

**Description:** A public pool that is maintained or operated in a manner that creates an unhealthful, unsafe, or unsanitary condition may be closed by the enforcing agent. Unhealthful, unsafe, or unsanitary conditions include, but are not limited to, failure to maintain clean pool water and clear pool water requirements; inadequate disinfection; improper pH; the presence of inhalation hazards; failure to meet microbiological or chemical water-quality standards; missing or broken suction outlet covers; missing or broken pool enclosures, including fencing and gates; hazards to pool users; and any other violation of these regulations identified by the enforcing agent. A public pool shall not be reopened until the unhealthful, unsafe, or unsanitary condition has been rectified and upon specific written approval from the enforcing agent.

#### Overall Inspection Comments

Note: Facility under new management. Manager not available on site at time of inspection. Provide department with access to equipment room.

#### Signature(s) of Acknowledgement

NAME:  
TITLE:

Total # of Images: 0