



**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>VILLA GABRIEL HOA</b>		REINSPECTION DATE <b>Not Specified</b>	INSPECTOR <b>Ngoc Le</b>	DATE <b>9/16/2016</b>
LOCATION <b>8300 GABRIEL DR, RANCHO CUCAMONGA, CA 91730</b>		PERMIT EXPIRATION <b>10/31/2016</b>	IDENTIFIER: Pool SERVICE: 001 - INSPECTION - ROUTINE	
TIME IN <b>3:55 PM</b>	TIME OUT <b>4:30 PM</b>	FACILITY ID <b>FA0004427</b>	RELATED ID <b>PR0015418</b>	PE <b>3620</b>
		RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED		

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

**92**  
SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	80
volume (gal)	29,000
area (sq ft)	940
occupancy	42

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K995 Permit - Suspension** **⚠ CRITICAL ⚠**

<b>POINTS</b> <b>NA</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Permit temporarily suspended due to high pH concentration.
	<b>Not In Compliance</b>	Close sign is posted. Do not reopen without approval from Environmental Health Services.
	Violation Reference - <b>HSC</b>	Call 1-800-442-2283 when ready to open.

**Violation Description:** Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval of EHS, may result in an hourly billable Professional Services fee.

**36K506 Water Quality - Critical – Water pH 7.2 to 7.8** **⚠ CRITICAL ⚠**

<b>POINTS</b> <b>5</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Measured pH concentration to be at 8.2.
	<b>Not In Compliance</b>	Maintain pH concentration between the required ranges of pH 7.2 to 7.8.
	Violation Reference - <b>HSC - 65530</b>	

**Violation Description:** The pool operator shall maintain public pool water at pH 7.2 to 7.8.



## RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME VILLA GABRIEL HOA	DATE 9/16/2016
LOCATION 8300 GABRIEL DR, RANCHO CUCAMONGA, CA 91730	INSPECTOR Ngoc Le

### 36K527 Safety – Safety signs

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed no CPR illustrated diagram.  Provide an illustrated diagram with text at least 1/4 inch high of CPR procedures.
	Not In Compliance	
	Violation Reference - CCR - 3120B	

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- Maximum number of pool users permitted for each pool.
- ""NO DIVING"" at pools with a maximum water depth of 6 feet or less.
- Where no lifeguard service is provided, a warning sign shall be posted stating, ""WARNING: NO LIFEGUARD ON DUTY."" The sign also shall state in letters at least 1 inch high, ""Children under the age of 14 shall not use pool without a parent or adult guardian in attendance.""
- An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- A warning sign for spa pools with ""CAUTION"" language.
- Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, ""NO USE OF POOL ALLOWED AFTER DARK.""
- A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, ""KEEP GATE CLOSED"" or ""KEEP DOOR CLOSED"".
- A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, ""CAUTION: WATER IS RECIRCULATED. DO NOT DRINK.""

### 36K548 Equipment - General Requirements - System Description

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed no float assembly within south-side skimmer.  Provide a float assembly for skimmer.
	Not In Compliance	
	Violation Reference - CCR 24 - 3123B.1	

**Violation Description:** Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The system shall consist of pumps, filters, chemical feeders, skimmers or perimeter overflow systems, valves, pipes, connections, fittings and appurtenances.

### 36K576 Maintenance – Operation/Incident records

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Chlorine tablets was observed in skimmer baskets of the pool.  Discontinue this practice. All chlorine must be applied through an approved automatic chlorinator.
	Not In Compliance	
	Violation Reference - HSC - 65523	

**Violation Description:** The pool operator shall maintain a written daily record of all test results, equipment readings, calibrations, and corrective action taken at the public pool site. [This includes daily records of pH, disinfectant level, and water temperature. If used, cyanuric acid concentration shall be tested monthly.]

If a fecal, vomit, blood contamination, near-drowning, or drowning incident occurs in a pool, the pool operator shall record the incident in accordance with the requirements of [Health and Safety Code] section 65546 and shall identify the affected public pool in the incident record if there is more than one pool at the public pool site. This record shall be maintained at the public pool site.

### 36K596 Permit - Public Pool Closure

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Pool is closed due to high pH concentration.  Close sign is posted. Do not reopen without approval from Environmental Health Services.  Call 1-800-442-2283 when ready to open.
	Not In Compliance	
	Violation Reference - HSC - 65545	

**Description:** A public pool that is maintained or operated in a manner that creates an unhealthful, unsafe, or unsanitary condition may be closed by the enforcing agent. Unhealthful, unsafe, or unsanitary conditions include, but are not limited to, failure to maintain clean pool water and clear pool water requirements; inadequate disinfection; improper pH; the presence of inhalation hazards; failure to meet microbiological or chemical water-quality standards; missing or broken suction outlet covers; missing or broken pool enclosures, including fencing and gates; hazards to pool users; and any other violation of these regulations identified by the enforcing agent. A public pool shall not be reopened until the unhealthful, unsafe, or unsanitary condition has been rectified and upon specific written approval from the enforcing agent.



**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME VILLA GABRIEL HOA	DATE 9/16/2016
LOCATION 8300 GABRIEL DR, RANCHO CUCAMONGA, CA 91730	INSPECTOR Ngoc Le

**Overall Inspection Comments**

Pool is closed due to high pH concentration.

Close sign is posted. Do not reopen without approval from Environmental Health Services.

Call 1-800-442-2283 when ready to open.

Access to pump room was unable at the time of this inspection. Cannot determine if additional requirements are being met regarding records, GFCI, pool test kits, gauges, flow meter, leaks, and general maintenance of pump system.

**Signature(s) of Acknowledgement**

SNA

NAME: SNA  
TITLE:

Total # of Images: 0