



**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>FONTANA HIGH SCHOOL</b>			REINSPECTION DATE <b>Next Routine</b>	INSPECTOR <b>Patrick Baccari</b>	DATE <b>9/22/2015</b>
LOCATION <b>9453 CITRUS AV, FONTANA, CA 92335</b>			PERMIT EXPIRATION	IDENTIFIER: Pool	
TIME IN <b>10:47 AM</b>	TIME OUT <b>11:29 AM</b>	FACILITY ID <b>FA0005773</b>	RELATED ID <b>PR0014957</b>	PE <b>3603</b>	SERVICE: 001 - INSPECTION - ROUTINE RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE ACTION: 01 - NO FURTHER ACTION REQUIRED

**RECREATIONAL HEALTH - Public School Pool / Spa**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.




**99**

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	80.0
observed flow (gpm)	493
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K572 Maintenance – Pool shell cleanliness; slime and algae**

<b>POINTS</b> <b>1</b>	Compliance Date: <b>Not Specified</b>	Inspector Comments: <b>Observed wind blown debris on decking.</b>
	<b>Not In Compliance</b>	
	Violation Reference - <b>HSC - 65533</b>	<b>Provide regular scheduled cleaning to decking around pool to remove waste.</b>

**Violation Description:** (a) The pool operator shall maintain clean pool water while the public pool is in use. The pool operator shall not allow debris, including, but not limited to, floating scum, sputum, trash, or leaves, to accumulate in the public pool. The pool operator shall ensure that water levels are maintained and operated to remove such material continuously through the pool skimming system in accordance with section 3136B, Title 24, California Code of Regulations.

(b) The pool operator shall clean the bottom, sides, and other surfaces of the public pool as often as necessary to keep the bottom, sides, and public pool surfaces clean and free of slime and algae.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Signature(s) of Acknowledgement**

NAME:  
TITLE:

Total # of Images: 0