





**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>ONTARIO HIGH SCHOOL</b>				REINSPECTION DATE <b>Next Routine</b>	INSPECTOR <b>Veronica Martinez</b>	DATE <b>9/22/2015</b>
LOCATION <b>901 W FRANCIS ST, ONTARIO, CA 91761</b>				PERMIT EXPIRATION	IDENTIFIER: Diving Pool	
TIME IN <b>7:59 AM</b>	TIME OUT <b>8:30 AM</b>	FACILITY ID <b>FA0006432</b>	RELATED ID <b>PR0015640</b>	PE <b>3603</b>	SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
				RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED		
				ACTION: 01 - NO FURTHER ACTION REQUIRED		

**RECREATIONAL HEALTH - Public School Pool / Spa**

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K992 Permit Reinstatement**

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Compliance verified. The pool may open.
	Not In Compliance	
	Violation Reference - HSC	

**Description:** The health permit to operate is hereby reinstated and facility may open.

**36K994 Reinspection**

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> A reinspection was conducted today in regard to a pool closure due to high free chlorine observed during the last routine inspection.
	Not In Compliance	
	Violation Reference - HSC	

Upon reinspection, observed free chlorine measuring 8.30 ppm and pH measuring 7.7. The pool may open.

**Description:** Reinspection conducted at this time to determine compliance from prior inspection.

**Overall Inspection Comments**

Note: existing enclosure gates self closing and self latching when opening distance less than 2.5 feet. Ensure gates self close and self latch at any opening distance.

-According to pool operator, existing gates on order to be replaced.

**Signature(s) of Acknowledgement**

NAME: Ryan Alvarez  
TITLE:

Total # of Images: 0