



Public Health
Environmental Health Services




www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME NORMANDY APARTMENTS		DATE 6/23/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 10/31/2015
LOCATION 4700 N SIERRA WY, SAN BERNARDINO, CA 92404			INSPECTOR Tia Wilson	
MAILING ADDRESS 4700 N SIERRA WY, SAN BERNARDINO, CA 92404			IDENTIFIER: Pool	
			SERVICE: 008 - INSPECTION - ATTEMPTED	
TIME IN 5:49 PM	TIME OUT 6:01 PM	FACILITY ID FA0008854	RELATED ID PR0013763	PE 3620
			RESULT: 00 - NOT APPLICABLE	
			ACTION: 00 - NOT APPLICABLE	

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

- Meet the latest ANSI/APSP-16 performance standard
- Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K996 Attempted Inspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Observed managers office closed at time of arrival. Will come back during operating hours.
	Not In Compliance	
	Violation Reference - HSC	

Description: An inspection was attempted today. Another inspection will be attempted at a later date.

Overall Inspection Comments

Another inspection will be attempted at a later date.

Signature(s) of Acknowledgement

NAME: Signature not available
TITLE:

Total # of Images: 0