



Public Health
Environmental Health Services




www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME CRESTHAVEN APARTMENT HOMES		DATE 6/23/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 7/31/2015
LOCATION 6155 N PALM AV, SAN BERNARDINO, CA 92407			INSPECTOR Tia Wilson	
MAILING ADDRESS 6155 N PALM AV, SAN BERNARDINO, CA 92407			IDENTIFIER: Office pool	
TIME IN 9:42 AM	TIME OUT 9:55 AM	FACILITY ID FA0004515	RELATED ID PR0013770	PE 3620
<input checked="" type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE ACTION: 15 - PERMIT REINSTATED / FACILITY RE-OPEN				

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	20

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K992 Permit Reinstatement

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Observed low free chlorine residual in pool. Pool reopened.
	Not In Compliance	
	Violation Reference - HSC	

Description: The health permit to operate is hereby reinstated and facility may open.

36K994 Reinspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: A reinspection was conducted to verify compliance regarding lack of chlorine observed during routine inspection.
	Not In Compliance	
	Violation Reference - HSC	

Description: Reinspection conducted at this time to determine compliance from prior inspection.

36K504 Water Quality – Non-Critical – Disinfectant level low

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed free chlorine measuring 0.59 ppm. Maintain free chlorine between 2.0 ppm and 10.0 ppm for pool.
	Not In Compliance	
	Violation Reference - HSC - 65529	

Violation Description: The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

Overall Inspection Comments

Pool reopened due to free chlorine residual observed.

Signature(s) of Acknowledgement

NAME: Wendy Parker
TITLE: Manager



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME CRESTHAVEN APARTMENT HOMES	DATE 6/23/2015
LOCATION 6155 N PALM AV, SAN BERNARDINO, CA 92407	INSPECTOR Tia Wilson

Total # of Images: 0