



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

| | | | | |
|--|---------------------|--------------------------|--|---------------------------------|
| FACILITY NAME PINECREST CHRISTIAN CONFERENCE CTR | | DATE 7/29/2015 | REINSPECTION DATE Not Specified | PERMIT EXPIRATION 12/31/2015 |
| LOCATION 1140 PINECREST RD, TWIN PEAKS, CA 92391 | | | INSPECTOR Yvette Velasco | |
| MAILING ADDRESS PO BOX 409, TWIN PEAKS CA 92391 | | | IDENTIFIER: Pool | |
| <input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT | | | SERVICE: 001 - INSPECTION - ROUTINE | |
| TIME IN 2:36 PM | TIME OUT 3:06 PM | FACILITY ID FA0006903 | RELATED ID PR0007973 | PE 3620 |
| | | | RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE | |
| | | | ACTION: 01 - NO FURTHER ACTION REQUIRED | |

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.




98

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (°F) | 84.0 |
| observed flow (gpm) | No Data |
| required flow (gpm) | 0 |
| volume (gal) | 0 |
| area (sq ft) | No Data |
| occupancy | No Data |

IMPORTANT: Replacement of Suction Outlet Covers
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K504 Water Quality – Non-Critical – Disinfectant level low

| | | |
|---------------------------|-----------------------------------|--|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Observed free chlorine in the pool at 1.6 ppm. |
| | Not In Compliance | Ensure to maintain free chlorine at 2.0-10.0 ppm when using cyanuric acid. |
| | Violation Reference - HSC - 65529 | |

Violation Description: The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

36K546 Equipment – Non-Critical - Water treatment system operation

| | | |
|---------------------------|-----------------------------------|--|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Observed the flow meter stuck. |
| | Not In Compliance | Ensure to repair or replace flow meter. |
| | Violation Reference - HSC - 65525 | |

Violation Description: The pool operator shall operate pumps, filters, disinfectant and chemical feeders, flow indicators, gauges, recirculation systems, disinfection systems, and all parts of the water treatment system whenever the public pool is available for use, and at such additional times and periods as may be necessary to maintain clean pool water, clear pool water, and the disinfection standards required in section 65529 [Health and Safety Code].

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

| | |
|--|--|
| <small>FACILITY NAME</small> PINECREST CHRISTIAN CONFERENCE CTR | <small>DATE</small> 7/29/2015 |
| <small>LOCATION</small> 1140 PINECREST RD, TWIN PEAKS, CA 92391 | <small>INSPECTOR</small> Yvette Velasco |

A handwritten signature in blue ink that reads "Tim Alford".

NAME: Tim Alford
TITLE:

Total # of Images: 0