



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME HYATT PLACE		DATE 6/3/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 8/31/2015
LOCATION 4760 E MILLS CR, ONTARIO, CA 91764			INSPECTOR Shannon Johnson	
MAILING ADDRESS 42 CORPORATE PARK STE 200, IRVINE CA 92606-3104			IDENTIFIER: Pool	
TIME IN 11:16 AM			SERVICE: 001 - INSPECTION - ROUTINE	
TIME OUT 12:04 PM			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
FACILITY ID FA0000700			ACTION: 01 - NO FURTHER ACTION REQUIRED	
RELATED ID PR0015960			PE 3620	




RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

98
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	84.0
observed flow (gpm)	70
required flow (gpm)	56
volume (gal)	20,318
area (sq ft)	903
occupancy	45

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:
1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump
Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K504 Water Quality – Non-Critical – Disinfectant level low

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed the measure reading for free chlorine to be 1.73
	Not In Compliance	
	Violation Reference - HSC - 65529	

Violation Description: The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

36K576 Maintenance – Operation/Incident records

POINTS 1	Compliance Date: Not Specified	Inspector Comments: Observed no reading for cyanuric acid available on the daily records for review. Test and record at least once a month.
	Not In Compliance	
	Violation Reference - HSC - 65523	

Violation Description: The pool operator shall maintain a written daily record of all test results, equipment readings, calibrations, and corrective action taken at the public pool site. [This includes daily records of pH, disinfectant level, and water temperature. If used, cyanuric acid concentration shall be tested monthly.]

If a fecal, vomit, blood contamination, near-drowning, or drowning incident occurs in a pool, the pool operator shall record the incident in accordance with the requirements of [Health and Safety Code] section 65546 and shall identify the affected public pool in the incident record if there is more than one pool at the public pool site. This record shall be maintained at the public pool site.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME HYATT PLACE	DATE 6/3/2015
LOCATION 4760 E MILLS CR, ONTARIO, CA 91764	INSPECTOR Shannon Johnson

N S C

NAME:
TITLE:

Total # of Images: 0