



Public Health
Environmental Health Services




www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME LOCH LEVEN CHRISTIAN CONF CENTER		DATE 6/15/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 12/31/2015
LOCATION 8171 MOUNTAIN HOME CREEK RD, ANGELUS OAKS, CA 92305			INSPECTOR Tia Wilson	
MAILING ADDRESS 36910 MILLCREEK RD, MENTONE CA 92359			IDENTIFIER: Pool	
			SERVICE: 008 - INSPECTION - ATTEMPTED	
TIME IN 9:45 AM	TIME OUT 9:59 AM	FACILITY ID FA0006918	RELATED ID PR0006543	PE 3620
			RESULT: 00 - NOT APPLICABLE	
			ACTION: 00 - NOT APPLICABLE	

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	85
volume (gal)	41,010
area (sq ft)	1,040
occupancy	52

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K996 Attempted Inspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Director stated that the new pump had just been installed the previous day and that the pool will not be open for use until later in the month.
	Not In Compliance	
	Violation Reference - HSC	

Description: An inspection was attempted today. Another inspection will be attempted at a later date.

Overall Inspection Comments

Pool not open. Will attempt another inspection at a later date.

Signature(s) of Acknowledgement

NAME: Diana Lewis
TITLE: Office Assistant

Total # of Images: 0