




Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME TREE TOP LODGE			DATE 8/31/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 7/31/2016
LOCATION 27992 RAINBOW DR, LAKE ARROWHEAD, CA 92352				INSPECTOR Yvette Velasco	
MAILING ADDRESS PO BOX 186, LAKE ARROWHEAD CA 92352			<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT IDENTIFIER: Pool SERVICE: 008 - INSPECTION - ATTEMPTED RESULT: 00 - NOT APPLICABLE ACTION: 00 - NOT APPLICABLE		
TIME IN 10:09 AM	TIME OUT 10:22 AM	FACILITY ID FA0006788	RELATED ID PR0013615	PE 3620	

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	41
volume (gal)	15,000
area (sq ft)	510
occupancy	17

IMPORTANT: Replacement of Suction Outlet Covers
 Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K996 Attempted Inspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: A re-inspection of the pool was attempted. Observed pool area locked and manager not on site. Observed no key provided. Inspector will attempt at a later date.
	Not In Compliance	
	Violation Reference - HSC	

Description: An inspection was attempted today. Another inspection will be attempted at a later date.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME:
 TITLE:
 Total # of Images: 0