



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME VILLAGE AT SIERRA		REINSPECTION DATE Not Specified		INSPECTOR Genelle Guzman	DATE 6/6/2016
LOCATION 8684 SIERRA AV, FONTANA, CA 92335				PERMIT EXPIRATION 12/31/2016	IDENTIFIER: Pool
TIME IN 1:32 PM	TIME OUT 2:35 PM	FACILITY ID FA0010977	RELATED ID PR0013897	PE 3620	SERVICE: 001 - INSPECTION - ROUTINE
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE
					ACTION: 01 - NO FURTHER ACTION REQUIRED

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility


Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

95
SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	73
volume (gal)	26,265
area (sq ft)	824
occupancy	41

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K995 Permit - Suspension **⚠ CRITICAL ⚠**

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Observed levels of chlorine above 11.0 ppm. Maintain chlorine levels at 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. Corrected on site. Pool maintenance arrived during inspection. Retested chlorine levels to 5.53 ppm.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval of EHS, may result in an hourly billable Professional Services fee.

36K502 Water Quality - Critical – Disinfectant level **⚠ CRITICAL ⚠**

POINTS 5	Compliance Date: Not Specified	Inspector Comments: Observed chlorine levels measured above 11.0 ppm. Maintain chlorine levels at 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid.
	Not In Compliance	
	Violation Reference - HSC - 65529	

Violation Description: The minimum concentration of disinfectant residual in public pools shall be 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid. The minimum concentration of disinfectant residual in public spas, wading pools, and spray grounds shall be 3.0 ppm free-chlorine. The maximum concentration of disinfectant residual shall be 10.0 ppm free-chlorine.

The minimum concentration of bromine residual in public pools shall be 2.0 ppm. The minimum concentration of bromine residual in public spas, wading pools, and spray grounds shall be 4.0 ppm.

A spray ground and water features with an ultraviolet light disinfection system shall be disinfected continuously at a minimum of 40 mJ/cm2 by the ultraviolet light disinfection units while the spray ground and water features are in use. If the ultraviolet dosage rate drops below 40 mJ/cm2 the operator shall close the spray ground and water features.

Overall Inspection Comments

Observed levels of chlorine above 11.0 ppm.
Maintain chlorine levels at 1.0 ppm free-chlorine without cyanuric acid or 2.0 ppm free-chlorine with cyanuric acid.

Corrected on site. Pool maintenance arrived during inspection. Retested chlorine levels to 5.53 ppm.



Public Health
Environmental Health Services

www.SBCounty.gov
www.SBCounty.gov/dph/dehs

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME VILLAGE AT SIERRA	DATE 6/6/2016
LOCATION 8684 SIERRA AV, FONTANA, CA 92335	INSPECTOR Genelle Guzman

Signature(s) of Acknowledgement

NAME: Richard Parker
TITLE: Pool maintenance

Total # of Images: 0