



Public Health

Environmental Health Services

RECREATIONAL HEALTH PLAN CHECK - OFFICIAL PLAN REVIEW REP

FACILITY NAME MOUNTAIN SPRINGS		DATE 8/29/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION
LOCATION 1413 SAN BERNARDINO RD, UPLAND, CA 91768			INSPECTOR Bennetta Betbadal	
MAILING ADDRESS 1151 N DEL RIO PLACE ONTARIO, CA 91764			IDENTIFIER: None	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT			SERVICE: 025 - PLAN REVIEW	
TIME IN 7:33 AM	TIME OUT 7:50 AM	FACILITY ID FA0006123	RELATED ID SR0069659	PE 3755
			RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED	
			ACTION: 55 - PLANS APPROVED	

RECREATIONAL HEALTH PLAN CHECK - Plan Check Rec Health Consultation

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

37K980 Plans - Plan Review Approved

Compliance Date: Not Specified

Not In Compliance

Reference - HSC

Inspector Comments: Request is approved for installation of Pentair i1 Intelliflo Variable speed pump 1HP with 76 gpm

Description: Plans have been approved and this correction sheet is a part of the approved plans.

Overall Inspection Comments

- 1- Pump has to be locked at a speed that provides flow rate of 40 gpm.
- 2- The variable speed pump control pad must be password protected to prevent tampering.
- 3- Flow meter shall be functioning, accurate and readable.
- 4- The district health inspectors will verify these flow rates at each routine inspection.

Surface Area: 50 square feet

Capacity: 1200 gallon

Flow Rate: 40 gpm

Main Drain Suction Line: 2" with 84 gpm at 8 fps

Skimmer Suction Line: 2" with 84 gpm at 8 fps

Return Line: 2" with 105 gpm at 10 fps

Main drain and equalizer line covers: Paramount SDX

Filter: Pentair SMBW 2048 with 94 gpm

Proposed Pump: Pentair Intelliflo Variable speed pump 1HP, 76 gpm

Signature(s) of Acknowledgement

NAME:

TITLE:

Total # of Images: 0