



RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME INN AT SILVER LAKES				REINSPECTION DATE Not Specified	INSPECTOR Dawn LaFlower	DATE 1/8/2016
LOCATION 14818 CLUBHOUSE DR, HELENDALE, CA 92342				PERMIT EXPIRATION	IDENTIFIER: None	
TIME IN 1:03 PM	TIME OUT 1:36 PM	FACILITY ID FA0007283	RELATED ID CO0053074	PE 3620	SERVICE: 004 - COMPLAINT - INITIAL	
				RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU		
				ACTION: 03 - REINSPECTION REQUIRED		


RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:
1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump
Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K999 Complaint Inspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Environmental Health has received a complaint stating that pool at facility is green. Observed heavy algae and debris build up on top and sides of pool. Observed algae and debris on bottom of pool with main drain visible. Manager states that equipment is in disrepair.
	Not In Compliance	
	Violation Reference - HSC	

Description: A complaint report has been received by Environmental Health.

Overall Inspection Comments

Pool water must be maintained clean and clear.

A reinspection will be conducted in 4 business days on Thursday, January 14, 2016. Failure to comply will result in future charged reinspection billed at a rate of \$245.00 per hour with a 1/2 hour minimum.

Signature(s) of Acknowledgement

NAME: Nancy
TITLE: Front Desk

Total # of Images: 0