



Public Health
Environmental Health Services



www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME TERRACINA APARTMENT		DATE 6/5/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 1/31/2016
LOCATION 3303 S ARCHIBALD AV, ONTARIO, CA 91761			INSPECTOR Veronica Martinez	
MAILING ADDRESS 10505 SORRENTO VALLEY RD STE 300, SAN DIEGO CA 92121			IDENTIFIER: Office Pool	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
TIME IN 12:46 PM	TIME OUT 1:00 PM	FACILITY ID FA0005029	RELATED ID PR0017003	PE 3620
RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED				
ACTION: 15 - PERMIT REINSTATED / FACILITY RE-OPEN				

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	68
volume (gal)	24,700
area (sq ft)	840
occupancy	42

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K992 Permit Reinstatement

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Critical violation cited the during last routine inspection observed in compliance; gap between bottom of enclosure and dirt measuring less than 2 inches. Spa permit has been re-instated and spa is authorized to open by Division of Environmental Health Services (DEHS).
	Not In Compliance	
	Violation Reference - HSC	

Description: The health permit to operate is hereby reinstated and facility may open.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME:
TITLE:

Total # of Images: 0