



**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>VICTORVILLE SHADY OASIS CAMPGROUND</b>				REINSPECTION DATE <b>Not Specified</b>	INSPECTOR <b>Melissa Nano</b>	DATE <b>9/10/2015</b>
LOCATION <b>16530 STODDARD WELLS RD, VICTORVILLE, CA 92392</b>				PERMIT EXPIRATION <b>2/28/2016</b>	IDENTIFIER: Pool	
TIME IN <b>11:11 AM</b>	TIME OUT <b>11:43 AM</b>	FACILITY ID <b>FA0009170</b>	RELATED ID <b>PR0014039</b>	PE <b>3620</b>	SERVICE: 001 - INSPECTION - ROUTINE RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE ACTION: 01 - NO FURTHER ACTION REQUIRED	

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.



**97**

SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	68
volume (gal)	32,000
area (sq ft)	800
occupancy	40

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K508 Water Quality – Non-Critical – Water pH 7.2 to 7.8**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Maintain pH level between 7.2 and 7.8.  Observed pH at 6.9.
	Not In Compliance	
	Violation Reference - HSC - 65530	

**Violation Description:** The pool operator shall maintain public pool water at pH 7.2 to 7.8.

**36K518 Water Quality – Cyanuric acid concentration**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Maintain cyanuric acid concentration no more than 100ppm.  Observed concentration exceed 100ppm.
	Not In Compliance	
	Violation Reference - HSC - 65530	

**Violation Description:** The maximum concentration of cyanuric acid in public pool water shall not exceed 100.0 ppm.

**36K576 Maintenance – Operation/Incident records**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Maintain daily records of pH and chlorine measurements readily available on site.  Observed incomplete.
	Not In Compliance	
	Violation Reference - HSC - 65523	

**Violation Description:** The pool operator shall maintain a written daily record of all test results, equipment readings, calibrations, and corrective action taken at the public pool site. [This includes daily records of pH, disinfectant level, and water temperature. If used, cyanuric acid concentration shall be tested monthly.]

If a fecal, vomit, blood contamination, near-drowning, or drowning incident occurs in a pool, the pool operator shall record the incident in accordance with the requirements of [Health and Safety Code] section 65546 and shall identify the affected public pool in the incident record if there is more than one pool at the public pool site. This record shall be maintained at the public pool site.

**Overall Inspection Comments**

If there are any questions, please contact Environmental Health Services or Melissa Nano at (800) 442-2283.



Public Health  
Environmental Health Services

[www.SBCounty.gov](http://www.SBCounty.gov)  
[www.SBCounty.gov/dph/dehs](http://www.SBCounty.gov/dph/dehs)

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME VICTORVILLE SHADY OASIS CAMPGROUND	DATE 9/10/2015
LOCATION 16530 STODDARD WELLS RD, VICTORVILLE, CA 92392	INSPECTOR Melissa Nano

**Signature(s) of Acknowledgement**

NAME: sabrina eudy

TITLE:

Total # of Images: 0