



Public Health
Environmental Health Services

www.SBCounty.gov

RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT

FACILITY NAME MCDONALD'S 14975		DATE 4/21/2015	REINSPECTION DATE 5/05/2015	PERMIT EXPIRATION 12/31/2015
LOCATION 1796 E LUGONIA AV, REDLANDS, CA 92374			INSPECTOR Yvette Velasco	
MAILING ADDRESS PO BOX 13490, PALM DESERT CA 92255			IDENTIFIER: None	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
TIME IN 4:20 PM	TIME OUT 4:43 PM	FACILITY ID FA0001652	RELATED ID PR0010703	PE 1622
RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU				
ACTION: 03 - REINSPECTION REQUIRED				

RETAIL FOOD PROTECTION - Public Eating PI (100-Up Seats)

16K994 Reinspection

Compliance Date: Not Specified
Not In Compliance
Reference - HSC

Inspector Comments: During the last routine inspection the maximum hot water in the facility was observed at the mop sink at 114F.

Inspector was contacted by the PIC. PIC stated that the water heater had since been repaired and the water temperature was observed at 120F. Observed the maximum water temperature in the facility at 108F at the mop sink.

Inspector will return to the facility within 24 hours to ensure that proper water temperatures are reached and maintained at the facility.

Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

No summary comments have been made for this inspection.

Signature(s) of Acknowledgement

NAME:
 TITLE:
Total # of Images: 0