



Public Health
Environmental Health Services



www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME FAIRWAY PARK CONDO POOL		DATE 6/30/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2015
LOCATION 3210 LITTLE MOUNTAIN DR, SAN BERNARDINO, CA 92405			INSPECTOR Tia Wilson	
MAILING ADDRESS 3210 LITTLE MOUNTAIN DR, SAN BERNARDINO, CA 92405			IDENTIFIER: Spa	
<input checked="" type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT			SERVICE: 008 - INSPECTION - ATTEMPTED	
TIME IN 11:29 AM	TIME OUT 11:31 AM	FACILITY ID FA0008899	RELATED ID PR0014189	PE 3623
RESULT: 00 - NOT APPLICABLE				
ACTION: 00 - NOT APPLICABLE				

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

No Violations Cited

Overall Inspection Comments

Unable to access spa. Attempted to contact operator at phone number listed. Another inspection will be attempted at a later date.

Signature(s) of Acknowledgement

NAME: Signature not available
TITLE:

Total # of Images: 0