



Public Health
Environmental Health Services

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

| | | | | |
|---|---------------------|--------------------------|---|--------------------------------|
| FACILITY NAME VAN LEUVEN 14 | | DATE 7/6/2015 | REINSPECTION DATE Not Specified | PERMIT EXPIRATION 6/30/2016 |
| LOCATION 25247 VAN LEUVEN ST, LOMA LINDA, CA 92354 | | | INSPECTOR Veronica Vazquez | |
| MAILING ADDRESS 715 E. BRIER DR, SAN BERNARDINO CA 92408 | | | IDENTIFIER: Pool | |
| | | | SERVICE: 001 - INSPECTION - ROUTINE | |
| TIME IN 12:45 PM | TIME OUT 1:20 PM | FACILITY ID FA0004338 | RELATED ID PR0015695 | PE 3620 |
| | | | RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU | |
| | | | ACTION: 03 - REINSPECTION REQUIRED | |

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

97

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$ 4.08 per 1 minute with a minimum time of 30 minutes, and a minimum charge of \$122.50.

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (°F) | No Data |
| observed flow (gpm) | 60 |
| required flow (gpm) | No Data |
| volume (gal) | No Data |
| area (sq ft) | No Data |
| occupancy | 16 |

IMPORTANT: Replacement of Suction Outlet Covers
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:
1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump
Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K527 Safety – Safety signs

| | | |
|---------------------------|--|---|
| POINTS 1 | Compliance Date: Not Specified | Inspector Comments: Provide the following signs; a) Capacity of pool. e) The nearest emergency number. |
| | Not In Compliance Violation Reference - CCR - 3120B | |

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

36K542 Enclosure – Non-Critical – Gates and doors self-closing and self-latching

| | | |
|---------------------------|--|--|
| POINTS 1 | Comply by: 7/8/2015 | Inspector Comments: Repair/replace torn mesh by pool gate handle. Observed gate mesh torn. Pool gate has rails. |
| | Not In Compliance Violation Reference - CCR - 3119B | |

Violation Description: Gates and doors shall be equipped with self-closing and self-latching devices. Gates and doors shall be capable of being locked during times when the pool is closed. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. The pool enclosure shall have at least one means of egress without a key for emergency purposes. The enclosure shall be constructed so that all persons will be required to pass through common pool enclosure gates or doors in order to gain access to the pool area. All gates and doors exiting the pool area shall open into a public area or a walkway accessible by all patrons of the pool.



Public Health
Environmental Health Services

www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

| | |
|--|--------------------------------------|
| FACILITY NAME VAN LEUVEN 14 | DATE 7/6/2015 |
| LOCATION 25247 VAN LEUVEN ST, LOMA LINDA, CA 92354 | INSPECTOR Veronica Vazquez |

IMPORTANT: Replacement of Suction Outlet Covers

Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

36K582 Maintenance - Public pool site maintenance

| | | |
|-------------------------------|-----------------------------------|---|
| POINTS 1 | Comply by: 7/8/2015 | Inspector Comments: Repair/replace pool light. Observed pool light timer on and light not tuning on. Will reinspect. |
| | Not In Compliance | |
| | Violation Reference - HSC - 65535 | |

Violation Description: The pool operator shall keep all parts of the public pool site well-maintained, including, but not limited to, the public pools, water treatment systems, ancillary facilities, signs, showers, toilets, dressing facilities, drinking fountains, diaper-changing stations, floors, walls, partitions, doors, and lockers.

Overall Inspection Comments

Call Veronica Vazquez at (800) 442-2283 with questions.

Signature(s) of Acknowledgement

NAME:
TITLE:

Total # of Images: 0