



Public Health
Environmental Health Services



www.SBCounty.gov

RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME ROSEWOOD APARTMENTS		DATE 5/6/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2015
LOCATION 26222 REDLANDS BL, LOMA LINDA, CA 92354			INSPECTOR Veronica Vazquez	
MAILING ADDRESS PO BOX 670, UPLAND CA 91786			IDENTIFIER: Spa	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT			SERVICE: 008 - INSPECTION - ATTEMPTED	
TIME IN 1:00 PM	TIME OUT 1:20 PM	FACILITY ID FA0008379	RELATED ID PR0014590	PE 3623
RESULT: 00 - NOT APPLICABLE				
ACTION: 00 - NOT APPLICABLE				

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	8

36K595 Construction – Construction or alterations

POINTS
1

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 3103B

Inspector Comments: Observed pool shell removed to do replaster. Observed sign stating pool will reopen 5/20/15.

Submit plans to Division of Environmental Health Services.

Main drains must be in compliance. Pool shell finish shall be white.

Violation Description: A person proposing to construct, renovate or alter a pool, ancillary facilities or equipment and appurtenances shall submit plans and specifications detailing compliance with this chapter to the enforcing agent for review and written approval prior to commencing construction and shall first be cleared by the enforcing agent before substitution if not an exact duplicate of the units being changed or replaced.

Overall Inspection Comments

Call Veronica Vazquez at (800) 442-2283 with questions.

Signature(s) of Acknowledgement

NAME:
TITLE:

Total # of Images: 0