



**Public Health**  
Environmental Health Services



www.SBCounty.gov

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME BONANZA MOBILE ESTATES		DATE 6/17/2015	REINSPECTION DATE Not Specified	PERMIT EXPIRATION 12/31/2015
LOCATION 13645 5TH ST B, YUCAIPA, CA 92399			INSPECTOR Tia Wilson	
MAILING ADDRESS 13645 5TH ST B, YUCAIPA, CA 92399			IDENTIFIER: Pool	
			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
TIME IN 9:06 AM	TIME OUT 9:35 AM	FACILITY ID FA0007228	RELATED ID PR0014976	PE 3620
			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP RE	
			ACTION: 15 - PERMIT REINSTATED / FACILITY RE-OPEN	

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K994 Reinspection**

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> A reinspection was conducted regarding low pH observed during a recent inspection.
	Not In Compliance	
	Violation Reference - HSC	

**Description:** Reinspection conducted at this time to determine compliance from prior inspection.

**36K994 Reinspection**

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed pH measuring 7.0. Facility in compliance. Pool reopened.
	Not In Compliance	
	Violation Reference - HSC	

**Description:** Reinspection conducted at this time to determine compliance from prior inspection.

**36K508 Water Quality – Non-Critical – Water pH 7.2 to 7.8**

<b>POINTS</b> <b>1</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed pH measuring 7.0. Maintain pH between 7.2 and 7.8.
	Not In Compliance	
	Violation Reference - HSC - 65530	

**Violation Description:** The pool operator shall maintain public pool water at pH 7.2 to 7.8.

**Overall Inspection Comments**

Observed pH measuring 6.7. Employee stated that approximately 30 ounces of sodium carbonate was added to water. Per product label, amount of product to apply is dependent on total alkalinity, pool volume, and measured pH. Observed pool volume between 10,000 and 20,000 gallons and total alkalinity measuring 126 ppm. Advised employee to add product according to instructions based on observations gathered during inspection. Final pH measuring 7.0. pH low but not grounds for closure. Pool reopened.

**Signature(s) of Acknowledgement**

*Rex McDaniel*

NAME: Rex McDaniel  
TITLE: Maintenance Manager



**Public Health**  
**Environmental Health Services**

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>BONANZA MOBILE ESTATES</b>	DATE <b>6/17/2015</b>
LOCATION <b>13645 5TH ST B, YUCAIPA, CA 92399</b>	INSPECTOR <b>Tia Wilson</b>

**Total # of Images: 0**