



## RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT

FACILITY NAME SUPER PENNY MART		REINSPECTION DATE 12/04/2018	INSPECTOR Steven Uhlman	DATE 11/20/2018
LOCATION 2060 E HIGHLAND AV, SAN BERNARDINO, CA 92404		PERMIT EXPIRATION 1/31/2019	IDENTIFIER: None	
TIME IN 9:00 AM	TIME OUT 9:23 AM	FACILITY ID FA0009587	RELATED ID PR0002403	PE 1683
		SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION		
		RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU		
		ACTION: 03 - REINSPECTION REQUIRED		

### RETAIL FOOD PROTECTION - Prepackaged (500-2499 SqFt)

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

#### 16K994 Reinspection

Compliance Date: Not Specified

Inspector Comments: Observed that the maximum hot water temperature is 114 F.

Not In Compliance

Provided hot water at a minimum temperature of 120 F.

Reference - HSC

Description: Reinspection conducted at this time to determine compliance from prior inspection.

#### 16K021 Hot and cold water available

Compliance Date: Not Specified

Inspector Comments: Observed that the maximum hot water temperature is 114 F.

Not In Compliance

Provide hot water at a minimum temperature of 120 F.

Violation Reference - HSC - 113953(c),  
114099.2(b)

Violation Description: An adequate, protected, pressurized, potable supply of hot water and cold water shall be provided at all times. (113953(c), 114099.2(b) 114101(a), 114189, 114192, 114192.1, 114195)

#### Overall Inspection Comments

Water temperature is still below 120 F.

Adjust the hot water heater until the minimum hot water temperature is at least 120 F.

Correct this within 48 hours.

Call us for a reinspection when ready.

#### Signature(s) of Acknowledgement

NAME: naser meltis

TITLE: manager

Total # of Images: 0