



**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>PARKVIEW APARTMENTS</b>			REINSPECTION DATE <b>Not Specified</b>		INSPECTOR <b>Kelly Eredia</b>		DATE <b>6/22/2016</b>	
LOCATION <b>16350 PEBBLE BEACH DR, VICTORVILLE, CA 92392</b>				PERMIT EXPIRATION <b>10/31/2016</b>		IDENTIFIER: Pool		
TIME IN <b>4:10 PM</b>		TIME OUT <b>5:21 PM</b>		FACILITY ID <b>FA0005358</b>		RELATED ID <b>PR0015756</b>		SERVICE: 001 - INSPECTION - ROUTINE
				PE <b>3620</b>		RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQU		
						ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED		

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional inspection to be billed at the hourly rate as provided in the San Bernardino County Code, [Schedule of Fees](#).

**88**  
SCORE

Administrative Order to Show Cause (OSC): The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked; otherwise the right to a hearing shall be deemed waived.

See the following pages for the code sections and general requirements that correspond to each violation listed below.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	70
volume (gal)	34,000
area (sq ft)	800
occupancy	40

**IMPORTANT: Replacement of Suction Outlet Covers**  
Suction Outlet covers (anti-entrapment covers over main drains and skimmer equalizer outlets) shall be replaced upon expiration. The expiration (in years) is stamped on the front of each cover, indicating the amount of time the cover is valid after installation. Each replacement cover shall:

1. Meet the latest ANSI/APSP-16 performance standard
2. Be rated for the maximum designed flow-rate of the pump

Retain all records which indicate the make/model number of the replacement cover and date of installation. Records shall be made available to your inspector upon request.

**36K995 Permit - Suspension** **⚠ CRITICAL ⚠**

<b>POINTS</b> <b>NA</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Permit suspended due to main drain suction hazard.
	Not In Compliance	
	Violation Reference - HSC	

**Violation Description:** Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

**36K529 Safety – Critical – Main drain suction hazards** **⚠ CRITICAL ⚠**

<b>POINTS</b> <b>5</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed no Safety Vacuum Release System (SVRS) or an anti-entrapment device for single main drain pool. Ensure anti-entrapment device is provided for pool.
	Not In Compliance	
	Violation Reference - CCR - 3137B, 116064	

**Violation Description:** All suction outlets shall be equipped with suction fittings that meet the most recent ANSI/APSP performance standard.

All public wading pool suction outlets shall be covered with antivortex grates or similar protective devices. All suction outlets shall be covered with grates or antivortex plates that cannot be removed except with the use of tools. Slots or openings in the grates or similar protective devices shall be of a shape, area, and arrangement that would prevent physical entrapment and would not pose any suction hazard to bathers.

**36K518 Water Quality – Cyanuric acid concentration**

<b>POINTS</b> <b>1</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed cyanuric acid level high above 100.0 ppm. Ensure level does not exceed 100.0 ppm.
	Not In Compliance	
	Violation Reference - HSC - 65530	

**Violation Description:** The maximum concentration of cyanuric acid in public pool water shall not exceed 100.0 ppm.



## RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME PARKVIEW APARTMENTS	DATE 6/22/2016
LOCATION 16350 PEBBLE BEACH DR, VICTORVILLE, CA 92392	INSPECTOR Kelly Eredia

### 36K527 Safety – Safety signs

POINTS <b>1</b>	Compliance Date: Not Specified	Inspector Comments: Observed a) capacity b) emergency contact information c) facility address d) "keep gate closed" sign missing. Provide all safety information visibly on signs.
	Not In Compliance	
	Violation Reference - CCR - 3120B	

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

### 36K528 Safety – Safety equipment

POINTS <b>1</b>	Compliance Date: Not Specified	Inspector Comments: Observed life ring missing. Provide life ring at all times.
	Not In Compliance	
	Violation Reference - HSC - 65540	

**Violation Description:** Except for spray grounds without standing water, the pool operator shall ensure that the following safety and first aid equipment is provided and maintained readily visible and available for use at the public pool at all times:

- (1) A 17-inch-minimum (exterior diameter) life ring with an attached throw rope with a minimum 3/16-inch diameter. The throw rope shall be of sufficient length to span the maximum width of the public pool and shall be stored in such a way as to prevent kinking or fouling.
- (2) A 12-foot-minimum fixed-length rescue pole with a permanently attached body hook. For spas, the length of the rescue pole shall be of sufficient length to effectuate rescue.

For public pools that exceed 75 feet in length or 50 feet in width, the pool operator shall provide a rescue pole and a life ring on at least two opposing sides of the public pool at centralized locations.

For public pools with lifeguard personnel on duty, the pool operator of each public pool area shall have the following additional safety equipment:

- (1) A Red Cross 10-Person Industrial First Aid Kit or the equivalent.
- (2) An operating telephone.
- (3) A backboard and head immobilizer.

### 36K552 Equipment - Flow meter provided

POINTS <b>1</b>	Compliance Date: Not Specified	Inspector Comments: Observed flow meter not functioning. Ensure flow meter is functional.
	Not In Compliance	
	Violation Reference - CCR 24 - 3125B.3	

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow and installed according to the manufacturer's written instructions with increments in the range of normal flow.

### 36K556 Equipment – Plumbing labeled

POINTS <b>1</b>	Compliance Date: Not Specified	Inspector Comments: Observed no directional arrows on pool equipment pipes. Provide labels.
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	

**Violation Description:** The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area. Where the recirculation equipment for more than one pool is located on site, the equipment shall be marked as to which pool the system serves. Valves and plumbing lines shall be labeled clearly with the source or destination descriptions.



**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>PARKVIEW APARTMENTS</b>	DATE <b>6/22/2016</b>
LOCATION <b>16350 PEBBLE BEACH DR, VICTORVILLE, CA 92392</b>	INSPECTOR <b>Kelly Eredia</b>

**36K560 Equipment – Waste water**

<b>POINTS</b> <b>1</b>	<b>Compliance Date: Not Specified</b>	<b>Inspector Comments:</b> Observed diatomaceous earth draining into grass/ground. Ensure waste water drains into sanitary sewer.
	<b>Not In Compliance</b>	
	<b>Violation Reference - CCR - 3141B</b>	

**Violation Description:** There shall be no direct connection between the pool, its recirculation system or overflow drain to any sanitary sewer, storm drain or drainage system.

Material cleaned from filters and backwash water from any recirculation system shall be disposed in a manner that is acceptable to the local wastewater agency and will not create a nuisance. Backwash water shall not be returned to a pool. Pipes carrying wastewater from pools including pool drainage and backwash from filters shall be installed as an indirect waste in accordance with the requirements of Chapter 8 of the California Plumbing Code.

The backwash from a diatomaceous earth filter shall discharge into a separation tank that has been installed to collect the waste diatomaceous earth mixture. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

**36K562 Skimmers - Pool skimming systems**

<b>POINTS</b> <b>1</b>	<b>Compliance Date: Not Specified</b>	<b>Inspector Comments:</b> Observed a) weir gates missing b) trash in skimmers. Ensure all skimmer components are present, free of debris, and functioning properly.
	<b>Not In Compliance</b>	
	<b>Violation Reference - CCR - 3136B</b>	

**Violation Description:** The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 100 percent of the flow rate. Each surface skimmer shall comply with the requirements in accordance with section 3136B, Title 24, California Code of Regulations.

**Overall Inspection Comments**

Permit suspended due to main drain suction hazard. Contact the Department of Environmental Health's plan check at 800-442-2283 prior to installing an anti-entrapment device. Reinspection scheduled 2 weeks from today on 7/6/16.

**Signature(s) of Acknowledgement**

NAME: Maria Marquez  
TITLE: Property Manager

Total # of Images: 0